

APPLICATION FOR PERMIT TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF NEVADA

Date of filing in State Engineer's Office AUG 18 1975
Returned to applicant for correction SEP 17 1975
Corrected application filed NOV 13 1975
Map filed NOV 13 1975

The applicant Medispa Limited Partnership
6615 Reisterstown Road, of Baltimore
Maryland 21215, hereby make application for permission to appropriate the public waters of the State of Nevada, as hereinafter stated. (If applicant is a corporation, give date and place of incorporation; if a copartnership or association, give names of members.) Medispa Limited Partnership is a limited partnership of which Jerome S. Cardin and Jerome J. Collier are the general partners.

1. The source of the proposed appropriation is Underground
Name of stream, lake or other source.

2. The amount of water applied for is one and one-half (1 1/2) second-feet
One second-foot equals 448.83 gals. per min.

(a) If stored in reservoir give number of acre-feet acre-feet

3. The water to be used for Commercial (Health Spa)
Irrigation, power, mining, manufacturing, domestic, or other use.

4. If use is for:
(a) Irrigation (state number of acres to be irrigated)
(b) Stockwater (state number and kinds of animals to be watered)
(c) Other use (describe fully under "No. 12. Remarks") See #12, Remarks
(d) Power:

(1) Horsepower developed
(2) Point of return of water to stream

5. The water is to be diverted from its source at the following point: located in the NW 1/4 NW 1/4 of said Section 21, T.22S., R.61E., MDBM from which the NW corner of/Sec. 21 bears N 33° 49' 55" W. a distance of 1454.17 feet.
Describe as being within a 40-acre subdivision of public survey, and by course and distance to a section corner. If on unsurveyed land, it should be stated.

6. Place of use. N 1/2 NW 1/4, Section 21, T.22S., R.61E., on unsurveyed land.
Describe by legal subdivision, if on unsurveyed land it should be so stated.

7. Use will begin about Jan. 1 and end about Dec. 31, of each year.
Day and Month Day and Month

8. Description of proposed works. (Under the provisions of NRS 535.010 you may be required to submit plans and specifications of your diversion or storage works.) 50 HP Turbine pump, 5000 gal. steel storage pressure tank distribution water main with necessary valves, fittings, pumphouse and appurtenavces.
State manner in which water is to be diverted, whether by dam or other works, whether through pipes, ditches, flumes, or other conduits.

- 9. Estimated cost of works..... \$20,000.00 approx.
- 10. Estimated time required to construct works..... one year
- 11. Estimated time required to complete the application to beneficial use..... 5 years
- 12. Remarks: For use other than irrigation or stock watering, state number and type of units to be served or annual consumptive use. 450 gal per hour, 24 hours per day, 7 days per week throughout the year. (JC)

See attached sheet.

Applicant.....

By Medispa Limited Partnership
 By s/ Jerome S. Cardin, Gen. Partner
 6615 Reisterstown Road
 Baltimore, Maryland 21215

Compared..... jw/lk lk/bs

APPROVAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit is issued subject to existing rights and is further subject to revocation if and when water can be furnished by an entity such as a water district or a municipality engaged in furnishing water. A totalizing meter must be installed in the discharge pipeline, near the point of diversion, and accurate measurements must be kept of water placed to beneficial use. It is understood that this right must allow for a reasonable lowering of the static water level. The well shall be equipped with a 2-inch opening for measuring depth to water. If the well is flowing, a valve must be installed and maintained to prevent waste. This source is located within an area designated by the State Engineer pursuant to NRS 534.030. The State retains the right to regulate the use of the water herein granted at any and all times.

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, and not to exceed 0.5 cubic feet per second but not to exceed

3.942 million gallons annually.

Actual construction work shall begin on or before November 11, 1976

Proof of commencement of work shall be filed before December 11, 1976

Work must be prosecuted with reasonable diligence and be completed on or before November 11, 1977

Proof of completion of work shall be filed before December 11, 1977

Application of water to beneficial use shall be made on or before November 11, 1979

Proof of the application of water to beneficial use shall be filed on or before December 11, 1979

Map in support of proof of beneficial use shall be filed on or before

Commencement of work filed..... NOV 2 1976
 Completion of work filed..... FEB 1 1978
 Proof of beneficial use filed.....
 Cultural map filed.....
 Certificate No..... Issued.....
 Recorded..... Bk..... Page.....

IN TESTIMONY WHEREOF, I ROLAND D. WESTERGARD
 State Engineer of Nevada, have hereunto set my hand and the seal of
 my office, this 11th day of May

A.D. 1976 JAN 17 1980

CANCELLED
 OF APPLICANT TO COMPLY WITH THE PROVISIONS OF PERMIT
 William J. Geoman
 STATE ENGINEER

12. Remarks: (continued)

It is anticipated that the water will be used within the health spa to be constructed on the site. The use of the water will depend upon its' mineral content and since we are advised that the water has a temperature of 106° F, it is planned to pump the water from the well directly to the baths. For your information, we have been advised that this well was drilled in 1952 to a depth of 460' and was cased with a 10" I.D. pipe to the bottom. The static water level at that time was 82'. The well was tested to a capacity of 600 gal. per minute with a 200' draw down. The original water permit was #21892. This permit has been cancelled. We further are advised that a new water Permit #24952 was issued for this well to Heers Bros. in 1965. The static water level is not known at this time but is presumed to be about 150' from the information we have been able to develop. There is an existing 5000 gal. steel water tank at the well site and a power line which is not hooked up, exists to the well installation.

