

APPLICATION FOR PERMIT TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF NEVADA

Date of filing in State Engineer's Office MAY 13 1980

Returned to applicant for correction JUL 30 1980

Corrected application filed AUG 13 1980

Map filed AUG 13 1980

The applicant I.S. Soper, Regency Casino

P.O. Box 655 of Laughlin Nevada 89046

hereby make application for permission to appropriate the public waters of the State of Nevada, as hereinafter stated. (If applicant is a corporation, give date and place of incorporation; if a copartnership or association, give names of members.)

1. The source of the proposed appropriation is the underground aquifer

2. The amount of water applied for is 0.055 second-feet

(a) If stored in reservoir give number of acre-feet

3. The water to be used for Quasi municipal purposes

4. If use is for:

(a) Irrigation (state number of acres to be irrigated)

(b) Stockwater (state number and kinds of animals to be watered)

(c) Other use (describe fully under "No. 12. Remarks")

(d) Power:

(1) Horsepower developed

(2) Point of return of water to stream

5. The water is to be diverted from its source at the following point: A point within Government Lot 2, Section 13, T32S, R66E from which the center of the Section bears S 68°11'15" W 750.8' Section not divided into 40 acre parcels.

6. Place of use A portion of the north one-half of Section 13 being the east 500' of the south 820.60' of the northwest one-quarter Section 13 T32S, R66E except the southerly 100' thereof. The south 370.00' of Government Lot 2 lying east of the dedicated highway and that part of the south 830' of Government Lot 2 lying west of the dedicated highway.

7. Use will begin about January 1 and end about December 31, of each year.

8. Description of proposed works. (Under the provisions of NRS 535.010 you may be required to submit plans and specifications of your diversion or storage works.) Water will be diverted from the underground aquifer through a well 330' deep having an 8" casing with a turbine pump into pressure tank

- 9. Estimated cost of works \$20,000.00
- 10. Estimated time required to construct works 6 months
- 11. Estimated time required to complete the application to beneficial use 2 years
- 12. Remarks: For use other than irrigation or stock watering, state number and type of units to be served or annual consumptive use.

Usage will be for casino, restaurant, convenience store as well as other casino restaurant and motel. See attached tabulation for water consumption.

Applicant.....

By s/Robert J. McNutt
ROBERT J. MCNUTT
P.O. Box 539
Las Vegas, NV 89101

Compared bc/ja gk/bc

APPROVAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit is issued subject to existing rights. It is understood that the amount of water herein granted is only a temporary allowance and that the final water right obtained under this permit will be dependent upon the amount of water actually placed to beneficial use. It is also understood that this right must allow for a reasonable lowering of the static water level. This well shall be equipped with a two (2) inch opening for measuring depth to water. If the well is flowing, a valve must be installed and maintained to prevent waste. A totalizing meter must be installed and maintained in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to beneficial use. The totalizing meter must be installed before any use of water begins or before the Proof of Completion of Work is filed.

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, and not to exceed 0.055 cubic feet per second, but not to exceed 11.04 million gallons annually.

Actual construction work shall begin on or before N/A
 Proof of commencement of work shall be filed before N/A
 Work must be prosecuted with reasonable diligence and be completed on or before August 14, 1982
 Proof of completion of work shall be filed before September 14, 1982
 Application of water to beneficial use shall be made on or before August 14, 1985
 Proof of the application of water to beneficial use shall be filed on or before September 14, 1985
 Map in support of proof of beneficial use shall be filed on or before.....

Commencement of work filed OCT 14 1983
 Completion of work filed OCT 1 1985
 Proof of beneficial use filed OCT 1 1985
 Cultural map filed.....
 Certificate No. 11296 Issued JAN 16 1986

IN TESTIMONY WHEREOF, I PETER G. MORROS
 State Engineer of Nevada, have hereunto set my hand and the seal of my office, this 14th day of AUGUST

A.D. 19 81

 State Engineer

Regency Casino
Laughlin, NV

Job 8012
5/12/80

Calculations for Water Consumption

-Convenience Store	1,000
Regency Casino	
400 Customers @10	4,000
40 Seat Restaurant @50	2,000
Air Conditioning	1,500
-Casino 600 customers @10 gal/day	6,000
Restaurant 60 seats @50 gal/day	3,000
Motel 16 units @50 gal/day	800
Air Conditioning	3,000
-Additions to Crystal Palace	
Motel 74 units @50	3,700
Rec Veh Park 65 units @50	3,250
Add'l Customers 200 @10	2,000
	<hr/>
	30,250

Total anticipated consumption 30,250 gal/day

Consumption will vary from 30,000 to 40,000 gal/day

Average day 35,000 gal or 0.055 cfs (24.3gpm)

Max hour 50 gpm Max minute 100-120 gpm

Available Storage 10,000 gallons

Robert J. McNutt

