

APPLICATION FOR PERMIT

TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF NEVADA

Date of filing in State Engineer's Office AUG 15 1984

Returned to applicant for correction

Corrected application filed

Map filed AUG 15 1984 under 48040

The applicant TOPAZ LODGE ENTERPRISES

777 W. Second Street, Suite 220, of Reno, Nevada 89505

hereby make application for permission to appropriate the public waters of the State of Nevada, as hereinafter stated. (If applicant is a corporation, give date and place of incorporation; if a copartnership or association, give names of members.)

ROGER H. ELTON, JAMES J. PAGE, JR.

1. The source of the proposed appropriation is NEVADA CREEK

2. The amount of water applied for is 0.25 second-feet

(a) If stored in reservoir give number of acre-feet

3. The water to be used for COMMERCIAL

4. If use is for:

(a) Irrigation, state number of acres to be irrigated

(b) Stockwater, state number and kinds of animals to be watered

(c) Other use (describe fully under "No. 12, Remarks")

(d) Power:

(1) Horsepower developed

(2) Point of return of water to stream

5. The water is to be diverted from its source at the following point SW1/4 SW1/4 Section 29, T.10N., R.22E., M.D.B.&M. or at a point from which the SW corner of said Section 29 bears S.80°47'W. a distance of 390'

6. Place of use Portions of the NW1/4 Section 32, T.10N., R.22E., M.D.B.&M. and portions of the SW1/4 Section 29, T.10N., R.22E., M.D.B.&M.

7. Use will begin about JANUARY 1 and end about DECEMBER 31, of each year.

8. Description of proposed works. (Under the provisions of NRS 535.010 you may be required to submit plans and specifications of your diversion or storage works.) CONCRETE DIVERSION STRUCTURES, AND 2"

PIPELINE TO THE PLACE OF USE

9. Estimated cost of works. EXISTING

10. Estimated time required to construct works EXISTING CONCRETE DIVERSION STRUCTURE
If well completed, describe works.

11. Estimated time required to complete the application of water to beneficial use 3 years

12. Remarks: For use other than irrigation or stock watering, state number and type of units to be served or annual consumptive use.

(See attached Exhibit A)

C.E.S., INC.
By s/George M. Thiel
P.O. BOX 1989
MINDEN, NEVADA 89423

Compared b1/bc b1/bc

Protested _____

DENIAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby ~~grant~~^{deny} the same, subject to the following limitations and conditions:

This application is hereby denied on the grounds that the Walker River system is fully appropriated and approval of further diversions of its tributaries would conflict with and impair the value of existing rights.

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, and not to exceed _____ cubic feet per second _____

Work must be prosecuted with reasonable diligence and be completed on or before _____

Proof of completion of work shall be filed before _____

Application of water to beneficial use shall be made on or before _____

Proof of the application of water to beneficial use shall be filed on or before _____

Map in support of proof of beneficial use shall be filed on or before _____

Completion of work filed _____

Proof of beneficial use filed _____

Cultural map filed _____

Certificate No. _____ Issued _____

IN TESTIMONY WHEREOF, I, PETER G. MORROS
State Engineer of Nevada, have hereunto set my hand and the seal of

my office, this 19th day of March,

A.D. 19 85



State Engineer

EXHIBIT A

PROJECTED WATER DEMAND - TOPAZ LODGE

. 50 gpd/unit (RV Park) x 150 units=	7500 gpd
	<u>2.738 mga</u>
. 100 gpd/unit (Motel) x 100 units =	10,000 gpd
	<u>3.65 mga</u>
. Store 200 gpd x 365 = 73,000 gpa =	<u>0.073 mga</u>
. Gas Station 1500 gpd x 365 =	<u>0.548 mga</u>
. Casino expansion (check existing consumptive totals)	10,000 gpd
	<u>2.15 mga</u>
. Restaurant 1,000 gpd x 365 =	<u>0.365 mga</u>
. Landscaping	= 2,000 gpd
	<u>0.730 mga</u>
TOTAL	<u>10.181 mga</u>
+ existing (33664)	2.52 (Combined)
+ existing (33663)	_____
TOTAL COMBINED =	<u>12.701 MGA</u>