

ASSIGNED

No 48978

APPLICATION FOR PERMIT

TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF NEVADA

Date of filing in State Engineer's Office APR 09 1985

Returned to applicant for correction.....

Corrected application filed.....

Map filed APR 09 1985 under 48976

The applicant Southern Pacific Land Company

One Market Plaza, of San Francisco,
Street and No. or P.O. Box No. City or Town

California (94106), hereby make S application for permission to appropriate the public
State and Zip Code No.

waters of the State of Nevada, as hereinafter stated. (If applicant is a corporation, give date and place of incorporation; if a copartnership or association, give names of members.)

February 1912 in the State of California

1. The source of the proposed appropriation is Underground - Well No. 1
Name of stream, lake, spring, underground or other source

2. The amount of water applied for is 0.75 cfs second-foot
One second-foot equals 448.83 gals. per min.

(a) If stored in reservoir give number of acre-feet.....

3. The water to be used for Quasi-Municipal and Domestic
Irrigation, power, mining, manufacturing, domestic, or other use. Must limit to one use.

4. If use is for:

(a) Irrigation, state number of acres to be irrigated.....

(b) Stockwater, state number and kinds of animals to be watered.....

(c) Other use (describe fully under "No. 12. Remarks").....

(d) Power:

(1) Horsepower developed.....

(2) Point of return of water to stream.....

5. The water is to be diverted from its source at the following point NE 1/4 SW 1/4 Section 27, T20N,
Describe as being within a 40-acre subdivision of public

R22E, MDM or at a point from which the W 1/4 corner of said Section
survey, and by course and distance to a section corner. If on unsurveyed land, it should be so stated.

27 bears, N 60° 50' W a distance of 2,743.3 feet.

6. Place of use NW 1/4 NW 1/4, SW 1/4 NW 1/4, SE 1/4 NW 1/4, NW 1/4 SW 1/4, portion of NE 1/4 SW 1/4,
Describe by legal subdivision. If on unsurveyed land, it should be so stated.

Section 27, T20N, R22E, MDM.

7. Use will begin about January 1 and end about December 31, of each year.
Month and Day Month and Day

8. Description of proposed works. (Under the provisions of NRS 535.010 you may be required to submit plans and specifications of your diversion or storage works.) Drill well, install pump and motor,
State manner in which water is to be diverted, i.e. diversion structure, ditches and
water distribution system and storage tanks.
flumes, drilled well with pump and motor, etc.

9. Estimated cost of works \$300,000

10. Estimated time required to construct works Two years.
If well completed, describe works.

11. Estimated time required to complete the application of water to beneficial use Ten years.

12. Remarks: For use other than irrigation or stock watering, state number and type of units to be served or annual consumptive use.

This is a quasi-municipal use of water to serve 300 mobile homes and a commercial area consisting of service station, motel, restaurant, truck stop and related uses. Estimated use is 190 acre feet per annum.

By s/ Richard W. Arden Agent
950 Industrial Way
Sparks, Nevada (89431)

Compared jm/jf js/bc

Protested _____

APPROVAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit is issued subject to existing rights. It is understood that the amount of water herein granted is only a temporary allowance and that the final water right obtained under this permit will be dependent upon the amount of water actually placed to beneficial use. It is also understood that this right must allow for a reasonable lowering of the static water level. This well shall be equipped with a two (2) inch opening for measuring depth to water. If the well is flowing, a valve must be installed and maintained to prevent waste. A totalizing meter must be installed and maintained in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to beneficial use. The totalizing meter must be installed before any use of water begins, or before the Proof of Completion of Work is filed. This source is located within an area designated by the State Engineer, pursuant to NRS 534.030. The State retains the right to regulate the use of the water herein granted at any and all times.

This Permit does not extend the permittee the right of ingress and egress on public, private or corporate lands.

The issuance of this permit does not waive the requirements that the permit holder obtain other permits from State, Federal and local agencies.

(CONTINUED ON PAGE 2)

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, and not to exceed 0.75 cubic feet per second, but not to exceed 67.16 million gallons annually.

Work must be prosecuted with reasonable diligence and be completed on or before October 17, 1987

Proof of completion of work shall be filed on or before November 17, 1987

Application of water to beneficial use shall be made on or before October 17, 1990

Proof of the application of water to beneficial use shall be filed on or before November 17, 1990

Map in support of proof of beneficial use shall be filed on or before _____

Completion of work filed _____ IN TESTIMONY WHEREOF, I PETER G. MORROS
State Engineer of Nevada, have hereunto set my hand and the seal of

Proof of beneficial use filed _____ my office, this 17th day of October,

Cultural map filed _____ A.D. 19 85

Certificate No. _____ Issued _____
Peter G. Morros
State Engineer

FEB 15 1989
CANCELLED _____ BECAUSE OF FAILURE OF APPLICANT TO COMPLY WITH THE PROVISIONS OF PERMIT
Peter G. Morros
STATE ENGINEER

(PERMIT TERMS CONTINUED)

This permit is issued under the provisions of NRS 534.120(2) as a preferred use.

The total combined duty of water under Permits 48976, 48977 and 48978 shall not exceed 67.16 million gallons annually.

At least one ground water monitoring well is to be installed within the place of use of Permits 48976, 48977 and 48978 at a location satisfactory to the State Engineer before any diversion of groundwater from the production wells take place. The monitoring well must be suitably cased, perforated, sealed and capped and must penetrate at least 75 feet below the water table.

