

APPLICATION FOR PERMIT TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF NEVADA

Date of filing in State Engineer's Office. ~~MAY 18 1988~~ NEW PRIORITY DATE: AUG 16 1994

Returned to applicant for correction. JUN 2 1988

Corrected application filed.

Map filed. JUN 20 1988 under 52101

The applicant Ted L. and Zelpha E. Hodge 9815 Dixon Lane of Reno Nevada, hereby make application for permission to appropriate the public waters of the State of Nevada, as hereinafter stated. (If applicant is a corporation, give date and place of incorporation; if a copartnership or association, give names of members.)

Charles E. and Margi Miller

1. The source of the proposed appropriation is Underground Name of stream, lake, spring, underground or other source

2. The amount of water applied for is 1.0 second-feet One second-foot equals 448.83 gals. per min.

(a) If stored in reservoir give number of acre-feet.

3. The water to be used for Quasi-Municipal and Domestic Irrigation, power, mining, manufacturing, domestic, or other use. Must limit to one use.

4. If use is for:

(a) Irrigation, state number of acres to be irrigated.

(b) Stockwater, state number and kinds of animals to be watered.

(c) Other use (describe fully under "No. 12. Remarks").

(d) Power:

(1) Horsepower developed.

(2) Point of return of water to stream.

5. The water is to be diverted from its source at the following point being within the SE 1/4 SW 1/4 of section 22, T19N, R28E, M.D.M. or at a point from which the SW corner of said section survey, and by course and distance to a section corner. If on unsurveyed land, it should be so stated.

22 bears S. 48° 02' 00" W a distance of 1860.00 feet.

6. Place of use portions of the SE 1/4 NE 1/4, SW 1/4 NE 1/4, NE 1/4 SE 1/4, SE 1/4 SE 1/4 of section 21, T19N, R28E, M.D.M., NW 1/4 SW 1/4, NE 1/4 SW 1/4, SE 1/4 SW 1/4 and portions of the SW 1/4 SW 1/4, SE 1/4 NW 1/4 of section 22, T19N, R28E, M.D.M., portions of the NW 1/4 NW 1/4, NE 1/4 NW 1/4 of section 27. T19N, R28E, M.D.M.

7. Use will begin about January 1 and end about December 31, of each year. Month and Day

8. Description of proposed works. (Under the provisions of NRS 535.010 you may be required to submit plans and specifications of your diversion or storage works.) well, pumps storage, transmission mains State manner in which water is to be diverted, i.e. diversion structure, ditches and flumes, drilled well with pump and motor, etc.

9. Estimated cost of works \$50,000.00

10. Estimated time required to construct works.....two years.....  
If well completed, describe works.

11. Estimated time required to complete the application of water to beneficial use.....five years.....

12. Remarks: For use other than irrigation or stock watering, state number and type of units to be served or annual consumptive use.

A planned unit residential development of approximately 800 units

Well #1

By.....s/Roy H. Hibdon Agent #370  
1479 So. Wells Avenue, Suite 15  
Reno, Nevada 89502

Compared...jjk/jm.....am/se

Protested.....

APPROVAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit is issued subject to existing rights. It is understood that the amount of water herein granted is only a temporary allowance and that the final water right obtained under this permit will be dependent upon the amount of water actually placed to beneficial use. It is also understood that this right must allow for a reasonable lowering of the static water level. This well shall be equipped with a two (2) inch opening for measuring depth to water. If the well is flowing, a valve must be installed and maintained to prevent waste. A totalizing meter must be installed and maintained in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to beneficial use. The totalizing meter must be installed before any use of water begins, or before the Proof of Completion of Work is filed. This source is located within an area designated by the State Engineer, pursuant to NRS 534.030. The State retains the right to regulate the use of the water herein granted at any and all times.

This permit does not extend the permittee the right of ingress and egress on public, private or corporate lands.

The issuance of this permit does not waive the requirements that the permit holder obtain other permits from State, Federal and local agencies.

(CONTINUED ON PAGE 2)

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, and not to exceed.....1.0.....cubic feet per second, but not to exceed 108 acre-feet annually.

Work must be prosecuted with reasonable diligence and be completed on or before.....April 30, 1993

Proof of completion of work shall be filed on or before.....May 30, 1993

Application of water to beneficial use shall be made on or before.....April 30, 1996

Proof of the application of water to beneficial use shall be filed on or before.....May 30, 1996

Map in support of proof of beneficial use shall be filed on or before.....N/A

Completion of work filed.....JUN 04 1996..... IN TESTIMONY WHEREOF, I, R. MICHAEL TURNIPSEED, P.E.,

Proof of beneficial use filed..... office, this.....30th.....day of.....April.....

Cultural map filed..... A.D. 19.....91.....

Certificate No.....Issued.....

*[Signature]*  
State Engineer

(O)-5314 (Rev.)

~~CANCELLED~~ AUG 12 1994 BECAUSE OF FAILURE OF APPLICANT TO COMPLY WITH THE PROVISIONS OF PERMIT  
*[Signature]* STATE ENGINEER  
Rescinded 9-9-94

~~CANCELLED~~ JAN 05 1996 BECAUSE OF FAILURE OF APPLICANT TO COMPLY WITH THE PROVISIONS OF PERMIT  
*[Signature]* STATE ENGINEER  
Rescinded 6-4-96

(PERMIT TERMS CONTINUED)

This permit is issued under the provisions of NRS 534.120(2) as a preferred use. The total combined duty of water under Permits 52101 and 52102 shall not exceed 108 acre-feet annually.

Any well drilled under this permit shall be drilled in what has been described in the United States Geological Survey Water Supply Paper 2263 as the intermediate alluvial aquifer. Prior to the placement of any casing, the well log shall be submitted to the State Engineer for approval as to the placement of the perforations and the surface seal.

Any water system placed within the place of use of this permit is recommended to be to the standard acceptable to any local governmental agency in the event the water system becomes part of a larger regional system.

The amount of water granted under this permit shall be for inside water use only. Any surface water that is appurtenant to the place of use of this permit shall remain for outside water use.

This permit is issued for a total of 324 single family dwelling units at 300 gallons per day for inside use.

