

**ASSIGNED**

**Nº 54726**

**AMENDED**

**APPLICATION FOR PERMIT  
TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF NEVADA**

Date of filing in State Engineer's Office..... MAY 8 1990  
Returned to applicant for correction..... JUN 7 1990  
Corrected application filed..... JUN 19 1990  
Map filed..... JUN 19 1990

The applicant..... PINE GROVE FARMS INC.  
2608 CENTRAL AVE., of UNION CITY,  
Street and No. or P.O. Box No. City or Town  
CALIFORNIA 94587, hereby make... application for permission to appropriate the public  
State and Zip Code No.  
waters of the State of Nevada, as hereinafter stated. (If applicant is a corporation, give date and place of incorporation; if a  
copartnership or association, give names of members.)..... NEVADA CORP. 1989

1. The source of the proposed appropriation is..... AN UNDERGROUND SOURCE  
Name of stream, lake, spring, underground or other source
2. The amount of water applied for is..... 0.5 CFS..... second-feet  
One second-foot equals 448.83 gals. per min.  
(a) If stored in reservoir give number of acre-feet.....
3. The water to be used for..... QUASI-MUNICIPAL & DOMESTIC  
Irrigation, power, mining, manufacturing, domestic, or other use. Must limit to one use.
4. If use is for:  
(a) Irrigation, state number of acres to be irrigated.....  
(b) Stockwater, state number and kinds of animals to be watered.....  
(c) Other use (describe fully under "No. 12. Remarks")..... SEE REMARKS  
(d) Power:  
(1) Horsepower developed.....  
(2) Point of return of water to stream.....

5. The water is to be diverted from its source at the following point..... Located in the SE $\frac{1}{4}$ -SW $\frac{1}{4}$  of Section  
Describe as being within a 40-acre subdivision of public  
26, T. 19 N., R. 28 E., M.D.B. & M.; from a point that bears S 55° 57' 48" W. a  
survey, and by course and distance to a section corner. If on unsurveyed land, it should be so stated.  
distance of 1776.52 feet to the SW corner of said Section 26.

6. Place of use..... A portion of the SE $\frac{1}{4}$ -SW $\frac{1}{4}$ , NE $\frac{1}{4}$ -SW $\frac{1}{4}$ , NW $\frac{1}{4}$ -SE $\frac{1}{4}$ , SW $\frac{1}{4}$ -SE $\frac{1}{4}$  of Section 26,  
Describe by legal subdivision. If on unsurveyed land, it should be so stated.  
T. 19 N., R. 28 E., M.D.B. & M.

7. Use will begin about..... Jan 1..... and end about..... Dec 31....., of each year.  
Month and Day Month and Day
8. Description of proposed works. (Under the provisions of NRS 535.010 you may be required to submit plans and specifications of your diversion or storage works.)..... WELL, PUMP & DISTRIBUTION SYSTEM  
State manner in which water is to be diverted, i.e. diversion structure, ditches and flumes, drilled well with pump and motor, etc.
9. Estimated cost of works..... \$20,000

10. Estimated time required to construct works.....2 years.....  
If well completed, describe works.

11. Estimated time required to complete the application of water to beneficial use.....5 years.....

12. Remarks: For use other than irrigation or stock watering, state number and type of units to be served or annual consumptive use.

.....Proposed development for the place of use will consist of approximately  
.....60 residential homes.....

.....s/Barry Fitzpatrick  
By Barry Fitzpatrick S.W.R.S #817  
141 Industrial Way  
Fallon, NV 89406

Compared pm/ bp am/se

Protested 9/4/90 by T.C.I.D.

Pro. wdr. 8-15-91

.....APPROVAL.....OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit is issued subject to existing rights. It is understood that the amount of water herein granted is only a temporary allowance and that the final water right obtained under this permit will be dependent upon the amount of water actually placed to beneficial use. It is also understood that this right must allow for a reasonable lowering of the static water level. This well shall be equipped with a two (2) inch opening for measuring depth to water. If the well is flowing, a valve must be installed and maintained to prevent waste. A totalizing meter must be installed and maintained in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to beneficial use. The totalizing meter must be installed before any use of water begins, or before the Proof of Completion of Work is filed. This source is located within an area designated by the State Engineer, pursuant to NRS 534.030. The State retains the right to regulate the use of the water herein granted at any and all times.

This permit does not extend the permittee the right of ingress and egress on public, private or corporate lands.

The total combined duty of water under Permits 54726 and 54727 shall not exceed 21.18 million gallons annually.

(CONTINUED ON PAGE 2)

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, and not to exceed.....0.25.....cubic feet per second, but not to exceed 21.18

.....million gallons annually.....

Work must be prosecuted with reasonable diligence and be completed on or before.....November 4, 1993.....

Proof of completion of work shall be filed on or before.....December 4, 1993.....

Application of water to beneficial use shall be made on or before.....November 4, 1996.....

Proof of the application of water to beneficial use shall be filed on or before.....December 4, 1996.....

Map in support of proof of beneficial use shall be filed on or before.....N/A.....

Completion of work filed.....DEC 27 1994.....

Proof of beneficial use filed.....

Cultural map filed.....

Certificate No..... Issued.....

IN TESTIMONY WHEREOF, I, R. MICHAEL TURNIPSEED, P.E., State Engineer of Nevada, have hereunto set my hand and the seal of my

office, this.....4th.....day of.....November.....,

A.D. 19.....91.....

*[Handwritten Signature]*  
State Engineer

(PERMIT TERMS CONTINUED)

The issuance of this permit does not waive the requirements that the permit holder obtain other permits from State, Federal and local agencies.

Any well drilled under this permit shall be drilled in what has been described in the United States Geological Survey Water Supply Paper 2263 as the intermediate alluvial aquifer. In no instance shall the seal on this well be less than 100 feet below ground level.

This permit is issued subject to the letter from Truckee-Carson Irrigation District dated August 13, 1991 withdrawing their protest.

