

APPLICATION FOR PERMISSION TO CHANGE POINT OF DIVERSION, MANNER OF USE AND PLACE OF USE OF THE PUBLIC WATERS OF THE STATE OF NEVADA HERETOFORE APPROPRIATED

Date of filing in State Engineer's Office DEC 15 1992

Returned to applicant for correction.....

Corrected application filed..... Map filed MAY 16 1980 under 40509

The applicant Incline Village General Improvement District
893 Southwood Boulevard of Incline Village
Street and No. or P.O. Box No. City or Town

Nevada 89451 hereby make...Sapplication for permission to change the
State and Zip Code No.

Point of Diversion
Point of diversion, manner of use, and/or place of use

of water heretofore appropriated under Permit #40514
Identify existing right by Permit, Certificate, Proof or Claim Nos. If Decreed, give title of Decree and

identify right in Decree.

1. The source of water is Incline Creek (existing diversion)
Name of stream, lake, underground spring or other source.

2. The amount of water to be changed 2.0 cfs/1447.94 AF
Second feet, acre feet. One second foot equals 448.83 gallons per minute.

3. The water to be used for municipal
Irrigation, power, mining, industrial, etc. If for stock state number and kind of animals.

4. The water heretofore permitted for municipal
Irrigation, power, mining, industrial, etc. If for stock state number and kind of animals.

5. The water is to be diverted at the following point (Lot 1) NW $\frac{1}{4}$, SW $\frac{1}{4}$, Section 16, T.16N, R.18E,
Describe as being within a 40-acre subdivision of public survey and by course and
MDB&M. At a point from which the W $\frac{1}{4}$ corner of said Section 16 bears N 22° 50'
distance to a section corner. If on unsurveyed land, it should be stated.
57" W, a distance of 2487.93 ft. Burnt Creek Intake Structure

6. The existing permitted point of diversion is located within NE $\frac{1}{4}$, NE $\frac{1}{4}$, Section 14, T.16N., R.18E,
If point of diversion is not changed, do not answer.
MDB&M. At a point from which the NE corner of said Section 14 bears N 88° 58'
09" E, a distance 960.36 ft.

7. Proposed place of use See attached
Describe by legal subdivisions. If for irrigation state number of acres to be irrigated.

8. Existing place of use same as above
Describe by legal subdivisions. If permit is for irrigation, state number of acres irrigated. If changing place of use and/or manner of use of irrigation permit, describe acreage to be removed from irrigation.

9. Use will be from January 1 to December 31 of each year.
Month and Day Month and Day

10. Use was permitted from January 1 to December 31 of each year.
Month and Day Month and Day

11. Description of proposed works. (Under the provisions of NRS 535.010 you may be required to submit plans and specifications of your diversion or storage works.) existing lake intake
State manner in which water is to be diverted, i.e. diversion structure, ditches, pipes and flumes, or drilled well, etc.

12. Estimated cost of works none

13. Estimated time required to construct works none

N/A

14. Estimated time required to complete the application of water to beneficial use.....

15. Remarks: For use other than irrigation or stock watering, state number and type of units to be served or annual consumptive use:

See attached

Compared..... cl/nsr cl/cms By ~~893 Southwood Boulevard~~ s/Signature illegible Incline Village, Nevada 89451

Protested.....

APPROVAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit to change point of diversion of the waters of Lake Tahoe heretofore granted under Permit 40514 is issued subject to the terms and conditions imposed in said Permit 40514 and with the understanding that no other rights at the source shall be affected by the change proposed herein. A totalizing meter must be installed in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to a beneficial use. This permit is subject to the final allocation of the State of Nevada under the California-Nevada Interstate Compact Commission. The State retains the right to regulate the use of the water herein granted at any and all times.

This permit does not extend the permittee the right of ingress and egress on public, private or corporate lands.

The issuance of this permit does not waive the requirements that the permit holder obtain other permits from State, Federal and local agencies.

The total combined duty of water under Permits 19393; 40511, Certificate 14298; 40512, Certificate 13536; 40515, Certificate 13537; 43042, Certificate 13539; 52244, Certificate 14299; 58395; 58396; 62044; 62045; 62046; 62047; 62048, and 62049 shall not exceed 4,018.16 acre-feet annually.

The amount of water to be changed shall be limited to the amount which can be applied to beneficial use, and not to exceed 2.00 cubic feet per second but not to exceed 1,447.94 acre-feet annually.

Work must be prosecuted with reasonable diligence and be completed on or before January 9, 1998

Proof of completion of work shall be filed before February 9, 1998

Application of water to beneficial use shall be made on or before January 9, 2007

Proof of the application of water to beneficial use shall be filed on or before February 9, 2007

Map in support of proof of beneficial use shall be filed on or before N/A

Completion of work filed FEB 24 1998

Proof of beneficial use filed

Cultural map filed

Certificate No. Issued

IN TESTIMONY WHEREOF, I, R. MICHAEL TURNIPSEED, P.E. State Engineer of Nevada, have hereunto set my hand and the seal of my

office, this 9th day of January

A.D. 19 97

[Signature] R.E. State Engineer

Abrogated By Part 65135.0.007

7. Proposed place of use:

All of Sections 1, 2, 3, 9, 10, 11, 13, 14, 15, 16, 17, 21, 22, and 23 and the W $\frac{1}{2}$ and the W $\frac{1}{2}$ of the NE $\frac{1}{4}$ and the S $\frac{1}{2}$ of the SE $\frac{1}{4}$ of Section 24; and the S $\frac{1}{2}$ of Section 8 and the W $\frac{1}{2}$ and the W $\frac{1}{2}$ of the E $\frac{1}{2}$ of Section 12 and the E $\frac{1}{2}$ of Section 18 and portions of the SW $\frac{1}{4}$ of the SE $\frac{1}{4}$ and the SE $\frac{1}{4}$ of the SW $\frac{1}{4}$ of Section 19 and within the W $\frac{1}{2}$ of the NE $\frac{1}{4}$ and the E $\frac{1}{2}$ of the NW $\frac{1}{4}$ of Section 30 T.16N, R.18E, MDB&M; and the NE $\frac{1}{4}$ of the SW $\frac{1}{4}$ and the NW $\frac{1}{4}$ of the SE $\frac{1}{4}$, Section 30, T.16N, R.18E.

15. Remarks:

The Incline Village General Improvement District serves approximately 8,500 full-time residents; 3,300 seasonal residents (approximately 2 months/year); and about 781,000 tourist visitor-days per year. These tourist visitors stay in 746 hotel rooms and 801 condominium/timeshare units. The total number of residential units is 6,475, with 2,730 single family residences and 3,745 multiple residential units. In addition to domestic use, the District supplies water to commercial uses, including 324,355 ft² retail; 309,324 ft² office; 27,893 ft² other services; 216,907 ft² entertainment; and 177,190 ft² wholesale/storage. Population tourist accommodations estimates and commercial floor areas are based on data compiled by the Washoe County Department of Comprehensive Planning.