

14. Estimated time required to complete the application of water to beneficial use..... one year

15. Remarks: For use other than irrigation or stock watering, state number and type of units to be served or annual consumptive use:

the new well is to serve the residents in the Town of Baker and the surrounding area incorporated in the service area of the Baker Water and Sewer General Improvement District.

By s/Erik Beyer
1274 St. Alberts Drive
Reno, Nevada 89503

Compared..... bc/bc cl/bk

Protested.....

APPROVAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit to change the point of diversion and place of use of the waters of an underground source as heretofore granted under Permit 52382 is issued subject to the terms and conditions imposed in said Permit 52382 and with the understanding that no other rights on the source will be affected by the change proposed herein. The well shall be equipped with a 2-inch opening and a totalizing meter must be installed and maintained in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to beneficial use. The totalizing meter must be installed before any use of the water begins or before the Proof of Completion of Work is filed. If the well is flowing, a valve must be installed and maintained to prevent waste. The State retains the right to regulate the use of the water herein granted at any and all times.

This permit does not extend the permittee the right of ingress and egress on public, private or corporate lands.

The issuance of this permit does not waive the requirements that the permit holder obtain other permits from State, Federal and local agencies.

The permittee shall report to the State Engineer on a quarterly basis the effect of pumping the well under this permit on other previously existing wells that are located within 2,500 feet of the well under this permit.

(CONTINUED ON PAGE 2)

The amount of water to be changed shall be limited to the amount which can be applied to beneficial use, and not to exceed..... 1.0.....cubic feet per second, but not to exceed 20.44 million gallons annually.

Work must be prosecuted with reasonable diligence and be completed on or before..... November 29, 1996

Proof of completion of work shall be filed before..... December 29, 1996

Application of water to beneficial use shall be made on or before..... November 29, 2001

Proof of the application of water to beneficial use shall be filed on or before..... December 29, 2001

Map in support of proof of beneficial use shall be filed on or before..... N/A

Completion of work filed..... JUN 13 1997

Proof of beneficial use filed..... JAN 28 2003

Cultural map filed.....

Certificate No. 16454 issued 2-1-05

IN TESTIMONY WHEREOF, I, R. MICHAEL TURNIPSEED, P.E., State Engineer of Nevada, have hereunto set my hand and the seal of my office, this 29th day of November

A.D. 19 95
R. Michael Turnipseed P.E.
State Engineer

(PERMIT TERMS CONTINUED)

Any pumping of water under this permit may be limited or prohibited to prevent any unreasonable adverse effects on an existing domestic well located within 2,500 feet of the well under this permit, unless the holder of this permit and the owner of the domestic well have agreed to alternative measures that mitigate those adverse affects.

Monthly records shall be kept of the amount of water pumped from this well and the records submitted to the State Engineer on a quarterly basis within 15 days after the end of each calendar quarter.

Any well drilled, or any exploratory hole drilled under Permit 52832 must be plugged within sixty (60) days of the date of this notice in compliance with Nevada Division of Water Resources' "Regulations for Water Well and Related Drilling", adopted January 1990. A well is not required to be plugged when the well is utilized for domestic use to serve a single family residence in compliance with Nevada Water Law.