

**APPLICATION FOR PERMIT
TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF
NEVADA**

Date of filing in State Engineer's Office _____ MAR 20 1997 _____

Returned to applicant for correction _____

Corrected application filed _____

Map filed _____ JAN 9 1990 under 54302 _____

The applicant Elko County School District, hereby makes application for permission to appropriate the public waters of the State of Nevada, as hereinafter stated.

1. The source of the proposed appropriation is Underground
2. The amount of water applied for is 0.50 second-feet
 - (a) If stored in reservoir give number of acre-feet
3. The water to be used for municipal & domestic
4. If use is for:
 - (a) Irrigation, state number of acres to be irrigated
 - (b) Stockwater, state number and kinds of animals to be watered
 - (c) Other use (describe fully under No. 12. "Remarks")
 - (d) Power:
 - (1) Horsepower developed
 - (2) Point of return of water to stream
5. The water is to be diverted from its source at the following point SW1/4 NW1/4, Section 2, T.33N., R.56E., M.D.B.&M. or at a point from which the NW corner of said Section 2 bears N 7° 00' 00" W, a distance of 1,550.00 feet.
6. Place of Use portion of the NW1/4 and SW1/4, Section 2 and the NE1/4 and SE1/4 of Section 3, T.33N., R.56E., M.D.B.&M. (Refer to map filed under applications 54302 and 54303)
7. Use will begin about January 1st and end about December 31st, of each year.
8. Description of proposed works Drilled well with pump and motor, pipeline, storage tank & distribution system to school complex.
9. Estimated cost of works 100,000
10. Estimated time required to construct works The well has been completed to 300 feet with 8-5/8" O.D. casing and equipped with 10 H.P. submersible pump.
11. Estimated time required to complete the application of water to beneficial use 3 years
12. Remarks: Well serves a student body/faculty of approximately 2,000 persons along with irrigation of various athletic facilities and

62930

landscaped areas covering approximately 25 acres. Consumptive use of this and the second point of diversion will not exceed 100 acre feet/annum.

By s/ Dale C. Bugenig
Dale C. Bugenig, Agent
1105 Terminal Way, Suite 304
Reno, Nevada 89502

Compared gkl/CMS dl/cms

Protested _____

APPROVAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit is issued subject to existing rights. It is understood that the amount of water herein granted is only a temporary allowance and that the final water right obtained under this permit will be dependent upon the amount of water actually placed to beneficial use. It is also understood that this right must allow for a reasonable lowering of the static water level. This well shall be equipped with a two (2) inch opening for measuring depth to water. If the well is flowing, a valve must be installed and maintained to prevent waste. A totalizing meter must be installed and maintained in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to beneficial use. The totalizing meter must be installed before any use of water begins, or before the Proof of Completion of Work is filed. This source is located within an area designated by the State Engineer, pursuant to NRS 534.030. The State retains the right to regulate the use of the water herein granted at any and all times.

This permit does not extend the permittee the right of ingress and egress on public, private or corporate lands.

The well must be sealed with cement grout, concrete grout or neat cement from ground level to 100 feet.

The total combined duty of water under Permits 62930 and 62931 shall not exceed 100.0 acre-feet annually.

The issuance of this permit does not waive the requirements that the permit holder obtain other permits from State, Federal and local agencies.

The permittee shall report to the State Engineer on a quarterly basis the effect of pumping the well under this permit on other previously existing wells that are located within 2,500 feet of the well under this permit.

Any pumping of water under this permit may be limited or prohibited to prevent any unreasonable adverse effects on an existing domestic well located within 2,500 feet of the well under this permit, unless the holder of this permit and the owner of the domestic well have agreed to alternative measures that mitigate adverse effects.

(CONTINUED ON PAGE 2)

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, and not to exceed 0.50 cubic feet per second, **but not to exceed 100.0 acre-feet annually.**

Work must be prosecuted with reasonable diligence and be completed on or before:
N/A

Proof of completion of work shall be filed before:
N/A

Application of water to beneficial use shall be filed on or before:
June 7, 2002


Proof of the application of water to beneficial use shall be filed on or before:
July 7, 2002

Map in support of proof of beneficial use shall be filed on or before:
N/A


IN TESTIMONY WHEREOF, I, R. MICHAEL TURNIPSEED, P.E.,

State Engineer of Nevada, have hereunto set
my hand and the seal of my office

this 7th day of June, A.D. 1999



State Engineer



Completion of work filed N/A

Proof of beneficial use filed _____

Cultural map filed _____

Certificate No. _____ Issued _____

Abrogated By 6.107 0.50

1111
1111
1111