

AMENDED
APPLICATION FOR PERMIT TO APPROPRIATE THE PUBLIC
WATERS OF THE STATE OF NEVADA

Date of filing in State Engineer's Office AUG.01 2002

Returned to applicant for correction _____

Corrected application filed SEP.05 2002

Map filed AUG.01 2002

The applicant **KEITH THOMAS** hereby makes application for permission to appropriate the public waters of the State of Nevada, as hereinafter stated.

1. The source of the proposed appropriation is **Underground**
2. The amount of water applied for is **.05 c.f.s.** second feet.
 - (a) If stored in reservoir give number of acre-feet
3. The water to be used for **Commercial Use**
4. If use is for:
 - (a) Irrigation, state number of acres to be irrigated **N/A**
 - (b) Stockwater, state number and kind of animals to be watered **N/A**
 - (c) Other use (describe fully under No. 12. "Remarks") **N/A**
 - (d) Power:
 - (1) Horsepower developed **N/A**
 - (2) Point of return of water to stream **N/A**
5. The water is to be diverted from its source at the following point **Located in the SW $\frac{1}{4}$ -NE $\frac{1}{4}$ of Section 27, T.19 N., R.28 E., M.D.B.& M., or at a point from which the E $\frac{1}{4}$ corner of said Section 27 bears S 85°01'00" E a distance of 1921.00 feet.**
6. Place of Use **portions of the SW $\frac{1}{4}$ -NE $\frac{1}{4}$ and NW $\frac{1}{4}$ -SE $\frac{1}{4}$ of Section 27, T.19 N., R.28 E. M.D.B.& M., a total of 1.32 acres.**
7. Use will begin about **JAN 1** and end about **DEC 31** of each year.
8. Description of proposed works **Drilled Well, Pump, Storage Tank & Distribution System**
9. Estimated cost of works **\$10,000**
10. Estimated time required to construct works **2 year**
11. Estimated time required to complete the application of water to beneficial use **4 years**
12. Remarks: **Application is for a commercial service business with a consumptive rate not to exceed 1,500 G.P.D., or 547,500 gallons per year. Please see enclosed detail of consumptive use.**

s/Barry A. Fitzpatrick
By **Barry A. Fitzpatrick**
Barry A. Fitzpatrick, S.W.R.S. #817
137 Keddie Street
Fallon, Nevada 89406

Compared sg/cm³ lb/sam

Protested _____

APPROVAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit is issued subject to existing rights. It is understood that the amount of water herein granted is only a temporary allowance and that the final water right obtained under this permit will be dependent upon the amount of water actually placed to beneficial use. It is also understood that this right must allow for a reasonable lowering of the static water level. This well shall be equipped with a two (2) inch opening for measuring depth to water. If the well is flowing, a valve must be installed and maintained to prevent waste. A totalizing meter must be installed and maintained in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to beneficial use. The totalizing meter must be installed before any use of water begins, or before the Proof of Completion of Work is filed. This source is located within an area designated by the State Engineer, pursuant to NRS 534.030. The State retains the right to regulate the use of the water herein granted at any and all times.

This permit does not extend the permittee the right of ingress and egress on public, private or corporate lands.

The issuance of this permit does not waive the requirements that the permit holder obtain other permits from State, Federal and local agencies.

This permit is issued under the provisions of NRS 534.120(2) as a preferred use.

Any well drilled under this permit shall be drilled in what has been described in the United States Geological Survey Water Supply Paper 2263 as the intermediate alluvial aquifer. In no instance shall the seal on this well be less than 100 feet below ground level.

(CONTINUED ON PAGE 3)

**SUPPLEMENTAL INFORMATION FOR APPLICATION
TO APPROPRIATE WATER
KEITH THOMAS (CARPET CONNECTION)**

BATHROOM FACILITIES

2 toilets, 2 lavatory sinks 500 GPD

FUTURE BATHROOM FACILITY

1 toilet, 1 lavatory sink 250 GPD

LOUNGE AREA (EMPLOYEES)

2 kitchen sinks 150 GPD

FUTURE BUILDING ADDITION

2 toilets, 2 lavatory sinks 500 GPD

LANDSCAPE IRRIGATION

100 GPD

TOTAL ESTIMATED WATER CONSUMPTION 1,500 GPD

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, and not to exceed 0.05 cubic feet per second, **but not to exceed 0.5475 million gallons annually.**

Work must be prosecuted with reasonable diligence and be completed on or before:

March 25, 2005

Proof of completion of work shall be filed on or before:

April 25, 2005

Water must be placed to beneficial use on or before:

March 25, 2008

Proof of the application of water to beneficial use shall be filed on or before:

April 25, 2008

Map in support of proof of beneficial use shall be filed on or before:

N/A

IN TESTIMONY WHEREOF, I, HUGH RICCI, P.E.,

State Engineer of Nevada, have hereunto set
my hand and the seal of my office,

this 25th day of March, A.D. 2003


State Engineer

Completion of work filed _____

Proof of beneficial use filed _____

Cultural map filed N/A _____

Certificate No. _____ Issued _____