



THE STATE OF NEVADA

PERMIT TO APPROPRIATE WATER

Name of Permittee: CITY OF WEST WENDOVER, NEVADA AND
CITY OF WENDOVER, UTAH

Source: UNDERGROUND (PILOT #2)

Basin: PILOT CREEK VALLEY

Manner of Use: MUNICIPAL

Period of Use: JANUARY 1ST THROUGH DECEMBER 31ST

Priority Date: 09/28/2012

APPROVAL OF STATE ENGINEER

This is to certify that I have examined the foregoing application, and do hereby grant the same, subject to the following limitations and conditions:

This permit is issued subject to existing rights. It is understood that the amount of water herein granted is only a temporary allowance and that the final water right obtained under this permit will be dependent upon the amount of water actually placed to beneficial use. It is also understood that this right must allow for a reasonable lowering of the static water level. This well shall be equipped with a two (2) inch opening for measuring depth to water. If the well is flowing, a valve must be installed and maintained to prevent waste. A totalizing meter must be installed and maintained in the discharge pipeline near the point of diversion and accurate measurements must be kept of water placed to beneficial use. The totalizing meter must be installed before any use of water begins or before the proof of completion of work is filed. This source is located within an area designated by the State Engineer pursuant to NRS 534.030. The State retains the right to regulate the use of the water granted herein at any and all times.

The total combined duty of water granted under Permits 82152, 82153 and 82156 shall not exceed 1,200 acre-feet annually.

Water from this permit shall not be pumped until a monitoring plan is approved by the State Engineer.

This permit does not extend the permittee the right of ingress and egress on public, private or corporate lands.

The issuance of this permit does not waive the requirements that the permit holder obtain other permits from State, Federal and local agencies.

The point of diversion and place of use are as described on the submitted application to support this permit.

(Continued on Page 2)

The amount of water to be appropriated shall be limited to the amount which can be applied to beneficial use, **and not to exceed 1.5 cubic feet per second or 400.0 acre-feet annually.**

Work must be prosecuted with reasonable diligence and proof of completion of work shall be filed on or before:

May 29 2020

Water must be placed to beneficial use and proof of the application of water to beneficial use shall be filed on or before:


May 29 2025

Map in support of proof of beneficial use shall be filed on or before:


N/A

IN TESTIMONY WHEREOF, I, JASON KING, P.E.,

State Engineer of Nevada, have hereunto set my hand and the seal of my office, this 29th day of May, 2015



State Engineer



AMENDED

Application No. 82153

APPLICATION FOR PERMIT TO APPROPRIATE THE PUBLIC WATERS OF THE STATE OF NEVADA

THIS SPACE FOR OFFICE USE ONLY	
Date of Filing in State Engineer's Office	<u>SEP 28 2012</u>
Returned to applicant for correction	<u>OCT 05 2012</u>
Corrected Application filed	<u>NOV 20 2012</u> Map filed <u>NOV 13 2012</u>

The applicant City of West Wendover, Nevada & City of Wendover, Utah

P.O. Box 2825 (Nevada) & 920 Wendover Boulevard (Utah) of City of West Wendover, Nevada & City of Wendover, Utah
Street Address or P.O. Box City or Town

89883 (Nevada) & 84083 (Utah) hereby make(s) application for permission to appropriate the
State and ZIP Code

public waters of the State of Nevada, as hereinafter stated. (If applicant is a corporation, give date and place of incorporation; if a copartnership or association, give names of members.)

1. The source of water is underground water well - Pilot #2
Name of the stream, lake, underground, spring or other sources.

2. The amount of water applied for is one and one-half second-feet (1.5 cfs)
One second foot equals 448.83 gallons per minute.

(a) If stored in a reservoir give the number of acre-feet _____

3. The water is to be used for municipal & DOMESTIC SWC E-MAIL
Irrigation, power, mining, commercial, domestic or other use. Must be limited to one major use.

4. If use is for:

(a) Irrigation, state number of acres to be irrigated _____

(b) Stockwater, state number and kind of animals _____

(c) Other use (describe fully in No. 12) _____

(d) Power:

(1) Horsepower developed _____

(2) Point of return of water to stream _____

5. The water is to be diverted from its source at the following point: (Describe as being within a 40-acre subdivision of public survey, and by course and distance to a found section corner. If on unsurveyed land, it should be so stated.)

Northeast 1/4 Northwest 1/4 of Section 16, Township 36 North, Range 69 East, M.D.B.&M. (Nevada) or at a point from which the Northwest corner of said Section 16 bears N79° 41'42.55"W a distance of 2236.07 feet.

6. Place of use: (Describe by legal subdivision. If on unsurveyed land, it should be so stated)

Sections 7, 8, 9, 10, 15, 16, 17, & 18 Township 33 North, Range 70 East M.D.B.&M. (Nevada).

Sections 16, 17, & 18 Township 1 South, Range 19 West, S.L.B.&M. (Utah).

North 1/2 portions of Sections 19, 20, & 21 Township 1 South, Range 19 West, S.L.B.&M. (Utah).

Sections 5, 6, & 8 Township 34 North, Range 69 East, M.D.B.&M. (Nevada)

Sections 4, 5, 6, 7, 8, 9, 17, 18, 19, 20, 29, 30, 31, & 32 Township 35 North, Range 69 East, M.D.B.&M. (Nevada)

Sections 3, 4, 8, 9, 10, 15, 16, 17, 20, 21, 28, 29, 31, & 32 Township 36 North, Range 69 East, M.D.B.&M. (Nevada)

Sections 13, 14, 15, 22, 23, 24, 26, 27, 33, 34, & 35 Township 37 North, Range 69 East, M.D.B.&M. (Nevada)

7. Use will begin about January 1 and end about December 31 of each year.
Month and Day Month and Day

8. Description of proposed works. (Under the provisions of NRS 535.010 you may be required to submit plans and specifications of your diversion or storage works.) (State manner in which water is to be diverted, i.e. diversion structure, ditches and flumes, drilled well with a pump and motor, etc.)

Drilled and cased well, fitted with sanitary seal, pump and motor, pipelines, storage reservoir, booster pump station, and transmission system.

9. Estimated cost of works: \$2,000,000.00

10. Estimated time required to construct works: Fifteen (15) years

(If the well is complete, describe works.)

11. Estimated time required to complete the application of water to beneficial use: Fifteen (15) years

12. Provide a detailed description of the proposed project and its water usage (use attachments if necessary): (Failure to provide a detailed description may cause a delay in processing.)

Maximum annual consumptive use: 400 acre-feet

(0.553 cfs x 1.98 af/cfs-day x 365 days)

Peak day demand: 1.5 cfs

13. Miscellaneous remarks:

See Addendum

RECEIVED
2012 NOV 13 AM 11:20
STATE ENGINEERS OFFICE

Chris J. Melville, City Manager

cmelville@westwendovercity.com

E-mail Address

(775) 664-3081

Phone No.

Ext.

Type or print name clearly

Signature, applicant or agent

City of West Wendover

Company Name

P.O. Box 2825

Street Address or PO Box

West Wendover, NV 89883

City, State, ZIP Code

APPLICATION MUST BE SIGNED
BY THE APPLICANT OR AGENT