



WELL DRILLERS REPORT

Please complete this form in its entirety

1. OWNER Boyd Steele ADDRESS 4161 Canal St
Las Vegas, Nevada

2. LOCATION SW 1/4 SW 1/4 Sec. 35 T. 3 N/S R. 55 E. Limerick County
 PERMIT NO. _____

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	15	15
Hard Pan		15	35	20
Cemented Gravel		35	40	5
Gravel + Sand	X	40	120	80
Hard Pan		120	165	45
Gravel + Sand	X	165	180	15
Cemented Gravel		180	200	20

8. WELL CONSTRUCTION
 Diameter hole 1 7/8 inches Total depth 200 feet
 Casing record 8 3/8 + 2 - 200
 Weight per foot _____ Thickness 15 1/2

Diameter	From	To
<u>1 7/8</u> inches	<u>+ 2</u> feet	<u>200</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 200 feet

Perforations:
 Type perforation Factory
 Size perforation _____
 From 140 feet to 200 feet
 From _____ feet to _____ feet

RECEIVED

MAR 18 1982
 Div. of Water Resources
 Ranch Office - Las Vegas, Nev.

Date started 7-25, 1980
 Date completed 7-30, 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

9. WATER LEVEL
 Static water level 60 Feet below land surface
 Flow _____ G.P.M.
 Water temperature _____ ° F. Quality _____

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Water Well Services
 Address 5115 S. Industrial Rd ^{Las Vegas}
 Nevada contractor's license number 10791
 Nevada driller's license number 692
 Signed Benny F. Wood
 Date 7-30-80

BAILER TEST
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours