DIVISION OF WATER RESOURCES

Well No. 2

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10189
Permit No. 24598 27026
Basin WHITE RIVER
30057
30058

1. OWNER Nancy E. Cassidy ADDRESS 1402 Trollman Ave.
San Mateo, California 94401

2. LOCATION NE ¼ NW ¼ Sec. 9 T. 12 N/S R. 62 E. White Pine County
PERMIT NO.

3. TYPE OF WORK
New Well ☒ Recondition ☐
Deepen ☐ Other ☐

4. PROPOSED USE
Domestic ☐ Irrigation ☒ Test ☐
Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL
Cable ☒ Rotary ☐
Other ☐

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		0	10	10
Cement gravel		10	19	9
Sandy clay		19	124	105
Gravel & sand	x	124	126	2
Clay with streak of sand	x	126	204	78
~~Cement gravel~~				
Sticky clay		204	268	64
" "		268	276	8
Cement gravel	x	276	284	8
Small gravel	x	284	288	4
Sticky clay		288	314	26
Hard cement gravel		314	317	3
Sandy clay		317	326	9
" "		326	332	6
Cement gravel	x	332	334	2
Sandy clay		334	350	6
Cement gravel		350	356	6
" "		356	374	18
Clay with streaks of sand		374	385	11

Date started June 26, 19 68
Date completed July 20, 19 68

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1500	1800	85	5 hours

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 16 inches Total depth 385 feet
Casing record 385 ft.
Weight per foot 42 lbs. Thickness ¼

Diameter	From	To
16 inches	0 feet	385 feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet
inches	feet	feet

Surface seal: Yes ☒ No ☐ Type cement
Depth of seal 5 ft. feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 124 feet to 385 feet

Perforations:
Type perforation factory
Size perforation 3/16 x 2½
From 124 feet to 385 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 124 Feet below land surface 124
Flow 0 G.P.M.
Water temperature 50 °F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Francis McKay
Address 730 Rosewood Drive
Nevada contractor's license number 514
Nevada driller's license number
Signed Francis McKay
Date 8/4/68

USE ADDITIONAL SHEETS IF NECESSARY

5471