

OFFICE USE ONLY  
 Log No. 21179  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

1. OWNER Timothy G. McGowan ADDRESS P. O. Box 221  
Lund, Nevada 89317

2. LOCATION 1/4 Sec. 21 T. 12 N. R. 62 E. White Pine County  
 PERMIT NO. Block 25, Lot 2 Of The Lund Ten Acre Plots

3. TYPE OF WORK	4. PROPOSED USE	5. TYPE WELL
New Well <input checked="" type="checkbox"/> Recondition <input type="checkbox"/>	Domestic <input checked="" type="checkbox"/> Irrigation <input type="checkbox"/> Test <input type="checkbox"/>	Cable <input type="checkbox"/> Rotary <input checked="" type="checkbox"/>
Deepen <input type="checkbox"/> Other <input type="checkbox"/>	Municipal <input type="checkbox"/> Industrial <input type="checkbox"/> Stock <input type="checkbox"/>	Other <input type="checkbox"/>

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	6	6
Gravel & Clay Seams		6	70	64
Water Bearing Sand	X	70	71	1
Clay		71	91	20
Clay & Sand		91	95	4
Clay		95	104	9
Clay & Sand		104	111	7
Clay		111	131	20
Water Bearing Gravel	X	131	132	1
Clay		132	166	34
Porous Sandstone	X	166	176	10
Clay		176	183	7

8. WELL CONSTRUCTION

Diameter hole 12 inches Total depth 183 feet  
 Casing record \_\_\_\_\_  
 Weight per foot 16.94 Thickness 1.88

Diameter	From	To
<u>8</u> inches	<u>0</u> feet	<u>183</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 183 feet

Perforations:  
 Type perforation Factory  
 Size perforation 3/16" Slots 8 Rows  
 From 63 feet to 183 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started May 14 1980  
 Date completed May 17 1980

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air Test ~~WALKER TEST~~

G.P.M. <u>30</u>	Draw down <u>40</u> feet	<u>1 1/2</u> hours
G.P.M. <u>45</u>	Draw down <u>80</u> feet	<u>1 1/2</u> hours
G.P.M. <u>60</u>	Draw down <u>110</u> feet	<u>2</u> hours

9. WATER LEVEL

Static water level 65 Feet below land surface 65  
 Flow \_\_\_\_\_ G.P.M.  
 Water temperature Cold F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Don S. Christiansen  
 Address 557 Ely Ave., Ely, Nevada 89301  
 Nevada contractor's license number 14790  
 Nevada driller's license number 705  
 Signed Don S. Christiansen  
 Date June 5, 1980