

OFFICE USE ONLY  
 Log No. 31887  
 Permit No. \_\_\_\_\_  
 Basin. 13-207

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 11734

PRINT OR TYPE ONLY

1. OWNER Brent Gardner ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS \_\_\_\_\_

2. LOCATION NE 1/4 SW 1/4 Sec. 28 T. 12 N/S R. 62 E. White Pine County

PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock   
 5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material    | Water Strata | From | To  | Thick-ness |
|-------------|--------------|------|-----|------------|
| Sandy Soil  |              | 0    | 4   | 4          |
| Sand-gravel |              | 4    | 12  | 8          |
| Sandy clay  |              | 12   | 46  | 34         |
| gravel      | water        | 46   | 47  | 1          |
| Sandy clay  |              | 47   | 57  | 10         |
| gravel      | water        | 57   | 60  | 3          |
| Sandy Clay  |              | 60   | 68  | 8          |
| gravel      | water        | 68   | 70  | 2          |
| clay        |              | 70   | 72  | 2          |
| gravel      | water        | 72   | 85  | 13         |
| Sandy Clay  |              | 85   | 99  | 14         |
| gravel      | water        | 99   | 101 | 2          |

8. WELL CONSTRUCTION  
 Diameter \_\_\_\_\_ inches Total depth 101 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record \_\_\_\_\_  
 Weight per foot \_\_\_\_\_ Thickness 188  

| Diameter         | From           | To              |
|------------------|----------------|-----------------|
| <u>10</u> inches | <u>0</u> feet  | <u>50</u> feet  |
| <u>8</u> inches  | <u>50</u> feet | <u>80</u> feet  |
| <u>6</u> inches  | <u>80</u> feet | <u>101</u> feet |
| _____ inches     | _____ feet     | _____ feet      |
| _____ inches     | _____ feet     | _____ feet      |
| _____ inches     | _____ feet     | _____ feet      |

 Surface seal: Yes  No  Type concrete grout  
 Depth of seal 3-50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 80 feet  
 Perforations:  
 Type perforation mill  
 Size perforation 8  
 From 60 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started July 5 1989  
 Date completed July 21 1989

7. WELL TEST DATA

| Pump RPM  | Draw Down | After Hours Pump |
|-----------|-----------|------------------|
| <u>50</u> | <u>68</u> |                  |
|           |           |                  |
|           |           |                  |

9. WATER LEVEL  
 Static water level 2.5 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature \_\_\_\_\_ °F Quality \_\_\_\_\_

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Nathan R Maynard Contractor  
 Address P.O. Box 176 Lund NV 89317 Contractor  
 Nevada contractor's license number issued by the State Contractor's Board 0022864  
 Nevada contractor's driller's number issued by the Division of Water Resources 1538  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556  
 Signed Nathan R Maynard  
 By driller performing actual drilling on site or contractor  
 Date July 21 1989

BAILER TEST  
 G.P.M. 40 Draw down 14 feet 1 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours