

OFFICE USE ONLY  
 Log No. 77779  
 Permit No. 2107  
 Basin 2107

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 30968

1. OWNER Norris Hendrix ADDRESS AT WELL LOCATION 200 N. 20 W. Lund NV  
 MAILING ADDRESS Po Box 184 Lund NV 89317

2. LOCATION NW 1/4 NE 1/4 Sec 33 T. 12 N/S R. 62 E White Pine County White Pine  
 PERMIT NO. N/A Lot 5 Block 10 Lund town site Survey  
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....

4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock

5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>Pulled out 60' of old casing</u>				
<u>Leamed out too 10" and deepend</u>				
<u>Too 100'</u>				
<u>Rock gravel top soil</u>		<u>0</u>	<u>20</u>	
<u>Sandy clay</u>	<u>water</u>	<u>20</u>	<u>60</u>	
<u>Sand gravel</u>	<u>water</u>	<u>60</u>	<u>63</u>	
<u>Sandy clay</u>		<u>63</u>	<u>71</u>	
<u>Sand gravel</u>		<u>71</u>	<u>73</u>	
<u>Sandy clay</u>		<u>73</u>	<u>79</u>	
<u>Sand gravel</u>		<u>79</u>	<u>81</u>	
<u>Sandy clay</u>		<u>81</u>	<u>94</u>	
<u>Sand Gravel</u>		<u>94</u>	<u>96</u>	
<u>Clay</u>		<u>96</u>	<u>100</u>	

8. WELL CONSTRUCTION  
 Depth Drilled 100 Feet Depth Cased 100 Feet

HOLE DIAMETER (BIT SIZE)  
 From 10 Inches 0 Feet 100 Feet  
 To \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>5 7/8</u>	<u>12.9</u>	<u>.188</u>	<u>-1</u>	<u>100</u>

Perforations:  
 Type perforation mill  
 Size perforation 8 x 2.5" x 6 row  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From 60 feet to 100 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Neat Cement  
 Cement Grout  
 Concrete Grout

Depth of Seal 50

Placement Method:  Pumped  Poured

Gravel Packed:  Yes  No  
 From 50 feet to 100 feet

9. WATER LEVEL  
 Static water level 22 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality good

Date started Nov 26 1999  
 Date completed Dec 9 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>40</u>	<u>33</u>	<u>1 hr</u>

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Orvan R. Maynard Contractor  
 Address Po Box 14 Lund NV 89317 Contractor

Nevada contractor's license number issued by the State Contractor's Board 047226  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556

Signed Orvan Maynard  
 By driller performing actual drilling on site or contractor

Date Dec 13 - 99