

OFFICE USE ONLY  
 Log No. 39355  
 Permit No. \_\_\_\_\_  
 Basin. 179

**WELL DRILLER'S REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 14038

PRINT OR TYPE ONLY

1. OWNER Mary Goeringer ADDRESS AT WELL LOCATION Ice House Canyon  
 MAILING ADDRESS P.O. Box 209  
Ely, NV 89301

2. LOCATION NE  $\frac{1}{4}$  NW  $\frac{1}{4}$  Sec. 28 T. 16 N. R. 63 E. White Pine County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other

4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock

5. TYPE WELL  
 Cable  Rotary   
 Other

6. LITHOLOGIC LOG

| Material                     | Water Strata | From | To  | Thick-ness |
|------------------------------|--------------|------|-----|------------|
| Cemented Fine Grained Gravel |              | 0    | 60  | 60         |
| Course Cemented Gravel       |              | 60   | 100 | 40         |
| Cemented Gravels             |              | 100  | 150 | 50         |
| Clay and Gravel              |              | 150  | 170 | 20         |
| Cemented Gravels             |              | 170  | 190 | 20         |
| Cemented Gravels             |              | 190  | 240 | 50         |
| Clay and Gravel              | x            | 240  | 270 | 30         |
| Clay and Fine Gravel         |              | 270  | 340 | 70         |
| Clay and Course Gravels      | x            | 340  | 370 | 30         |
| Cemented Gravels             |              | 370  | 390 | 20         |
| Clay and Gravel              |              | 390  | 405 | 15         |

8. WELL CONSTRUCTION  
 Diameter 10" inches Total depth 405 feet  
 \_\_\_\_\_ inches  
 \_\_\_\_\_ inches  
 Casing record 6 in. 0 - 405  
 Weight per foot 12.92 Thickness .188

| Diameter        | From          | To              |
|-----------------|---------------|-----------------|
| <u>6</u> inches | <u>0</u> feet | <u>405</u> feet |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |
| _____ inches    | _____ feet    | _____ feet      |

Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 50 feet to 405 feet

Perforations:  
 Type perforation Factory  
 Size perforation 1/8" x 2 1/2" 6 Rows  
 From 200 feet to 385 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Date started 5-22, 19 92  
 Date completed 6-02, 19 92

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|----------|--------|-----------|------------------|
|          |        |           |                  |
|          |        |           |                  |
|          |        |           |                  |

Air Test 60 BAILER TEST 5  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours

9. WATER LEVEL  
 Static water level 200 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Christiansen Drilling, Inc.  
 Address 557 Ely Avenue, Ely, NV 89301  
 Nevada contractor's license number issued by the State Contractor's Board 14790  
 Nevada contractor's driller's number issued by the Division of Water Resources 641  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793  
 Signed [Signature]  
 Date 6-23-92