DIVISION OF WATER RESOURCES

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 10146
Permit No. 24256 + 35837
Basin STAR PEAK VALLEY

1. OWNER Kitty McCracken ADDRESS Cisco, Texas

2. LOCATION SW ¼ SE ¼ Sec. 14 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. 24256

3. TYPE OF WORK
New Well [X] Recondition [ ]
Deepen [ ] Other [ ]

4. PROPOSED USE
Domestic [ ] Irrigation [X] Test [ ]
Municipal [ ] Industrial [ ] Stock [ ]

5. TYPE WELL
Cable [X] Rotary [ ]
Other [ ]

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top soil		1	4	
Gravel		4	10	
Clay & Gravel		10	45	
Boulders		45	50	
Clay & Gravel		50	60	
Sandy Clay		60	80	
Sand & Gravel	X	80	95	
Clay & Gravel		95	100	
Sandy Clay & Gravel		100	120	
Cemented Sand & Gravel		120	130	
Sand & Gravel	X	130	140	
Sandy Clay & Gravel		140	145	
Cemented Sand & Gravel		145	150	
Sand & Gravel	X	150	155	
Clay & Gravel		155	165	
Sand & Gravel	X	165	170	
Clay & Gravel		170	180	
Cemented Sand & Gravel		180	185	
Clay & Gravel		185	190	

Date started June 8, 19.68
Date completed [redacted] 15, 19.68

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
1760	1200	90	4 hours

BAILER TEST
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION
Diameter hole 18 inches Total depth 190 feet
Casing record 190' - 16"
Weight per foot ..... Thickness 2.19

Diameter		From		To	
16	inches	1	feet	190	feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet
	inches		feet		feet

Surface seal: Yes [ ] No [X] Type .....
Depth of seal ..... feet
Gravel packed: Yes [ ] No [X]
Gravel packed from ..... feet to ..... feet

Perforations:
Type perforation 6 rows - 3/8" - 12' long
Size perforation 3/8"
From 70 feet to 190 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL
Static water level 80 Feet below land surface 80
Flow ..... G.P.M.
Water temperature cool ° F. Quality good

10. DRILLERS CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Jim Schooler
Address Box 833 Ely, Nevada
Nevada contractor's license number 9557
Nevada driller's license number 515
Signed Jim Schooler
Date May 17, 1968

USE ADDITIONAL SHEETS IF NECESSARY

5471