

OFFICE USE ONLY  
 Log No. 29579  
 Permit No. \_\_\_\_\_  
 Basin \_\_\_\_\_

**WELL DRILLERS REPORT**

Please complete this form in its entirety

NOTICE OF INTENT NO. 1659  
Hercules Gap

PRINT OR TYPE ONLY

1. OWNER Jack Bennett ADDRESS AT WELL LOCATION Hercules Gap  
 MAILING ADDRESS 44 Greendale Court  
Las Vegas, Nevada 89121  
 2. LOCATION NW ¼ Sec. 8 T. 17 N. & R. 63 E. White Pine County  
 PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. TYPE OF WORK  
 New Well  Recondition   
 Deepen  Other   
 4. PROPOSED USE  
 Domestic  Irrigation  Test   
 Municipal  Industrial  Stock  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sedimentary Gravel & Boulders		0	20	20
Clay		20	40	20
Loose Gravel		40	54	14
Water Bearing Gravel X		54	56	2
Clay & Gravel		56	110	54
Water Bearing Gravel X		110	113	3
Clay		113	120	7

8. WELL CONSTRUCTION  
 Diameter hole 10 inches Total depth 120 feet  
 Casing record \_\_\_\_\_  
 Weight per foot 16.94 Thickness .188  

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>120</u> feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

 Surface seal: Yes  No  Type Cement  
 Depth of seal 50 feet  
 Gravel packed: Yes  No   
 Gravel packed from 0 feet to 50 feet  
 Perforations:  
 Type perforation Factory & Torch  
 Size perforation 1/8" x 3" 6 Rows  
 From 60 feet to 120 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

9. WATER LEVEL  
 Static water level 52 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Christiansen Drilling, Inc. Contractor  
 Address 557 Ely Avenue, Ely, Nev. 89301 Contractor  
 Nevada contractor's license number 14790  
 Nevada contractor's drillers number 641  
 Nevada driller's license number 641 Actual Driller  
 Signed Jerald D. Christiansen Contractor  
 Date MAY 13, 1983

Date started May 7, 1983  
 Date completed May 9, 1983

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air Test ~~XXXXXXXXXX~~  
 G.P.M. 20 Draw down 48 feet 1/2 hours  
 G.P.M. 25 Draw down 68 feet 1 hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours