

ddd

WELL DRILLERS REPORT

Please complete this form in its entirety

NOTICE OF INTENT NO. 1662

PRINT OR TYPE ONLY

1. OWNER Janet Sanderson ADDRESS AT WELL LOCATION Cross Timbers Subdivision
 MAILING ADDRESS P. O. Box 1251
Ely, Nevada 89301

2. LOCATION SE $\frac{1}{4}$ SE $\frac{1}{4}$ Sec. 16 T. 17 N. & R. 63 E. White Pine County
 PERMIT NO. 82 Cross Timbers Subdivision Name
Issued by Water Resources Parcel No.

3. TYPE OF WORK
 New Well Recondition
 Deepen Other

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock

5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	6	6
Cemented Gravel		6	105	99
Water Bearing Gravel X		105	106	1
Clay Mud		106	125	19
Hard Pan		125	155	30
Water Bearing Gravel X		155	158	3
Clay Mud		158	168	10
Hard Pan		168	170	2

8. WELL CONSTRUCTION
 Diameter hole 10 inches Total depth 170 feet
 Casing record
 Weight per foot 12.92 Thickness 1.88

Diameter	From	To
<u>6</u> inches	<u>0</u> feet	<u>170</u> feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet
..... inches feet feet

Surface seal: Yes No Type Cement
 Depth of seal 50 feet
 Gravel packed: Yes No
 Gravel packed from 50 feet to 170 feet

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 3" 6 Rows
 From 100 feet to 170 feet
 From feet to feet

9. WATER LEVEL
 Static water level 100 feet below land surface
 Flow G.P.M. P.S.I.
 Water temperature Cold ° F. Quality Good

10. DRILLERS CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc.
Contractor
 Address 557 Ely Avenue, Ely, Nev. 89301
Contractor
 Nevada contractor's license number 14790
 Nevada contractor's drillers number 641
 Nevada driller's license number 641
Actual Driller
 Signed Jerrold D. Christiansen
Contractor
 Date April 25, 1984

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

Air Test ~~WATER TEST~~
 G.P.M. 25 Draw down 48 feet $\frac{1}{2}$ hours
 G.P.M. 35 Draw down 68 feet $\frac{1}{2}$ hours
 G.P.M. Draw down feet hours