WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 46627
Permit No.
Basin 179

NOTICE OF INTENT NO. 22960

1. OWNER John Rogan
MAILING ADDRESS HC 32 Box 32101 Ely NV 89301
ADDRESS AT WELL LOCATION 244 N Lot 97

2. LOCATION SW ¼ NE ¼ Sec. 21 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. N/A (Issued by Water Resources) | 5-601-33 (Parcel No.) | Cross Timbers (Subdivision Name)

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[X] Cable [ ] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	
gravel clay cobbles		2	25	
gravel		25	30	
Silty clay-gravel		30	65	
Black clay		65	90	
Black gravel		90	95	
Black clay gravel		95	135	
Black Rock	water	135	136	
Black clay-gravel		136	195	
Black rock gravel	water	195	197	
Black rock-gravel		197	240	

'94 SEP -8 A10:36 STATE ENGINEER

Date started July 12, 1994
Date completed Aug 18, 1994

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
8	175	1

8. WELL CONSTRUCTION
Depth Drilled 240 Feet Depth Cased 240 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
10 Inches		0 Feet	50 Feet
8 Inches		50 Feet	240 Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.9	.188	-1	240

Perforations:
Type perforation Mill
Size perforation ¼ x 2.5 x 6 row
From feet to feet
From 120 feet to 140 feet
From 180 feet to 200 feet
From 220 feet to 240 feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 240 feet

9. WATER LEVEL
Static water level 65 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature cool °F Quality Some salt

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Nathan R Maynard (Contractor)
Address Po Box 176 Lund NV 89317 (Contractor)

Nevada contractor's license number issued by the State Contractor's Board 0022869
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1556
Signed Owen Maynard (By driller performing actual drilling on site or contractor)
Date Sept 2 - 94

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627