WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

Log No. 48065
Permit No.
Basin 179

NOTICE OF INTENT NO. 24653

1. OWNER Cary Brunson
MAILING ADDRESS P.O. Box 775
Ely, NV 89301

ADDRESS AT WELL LOCATION 6 miles north of Ely

2. LOCATION SE ¼ NE ¼ Sec. 15 T. 17 N/S R. 63 E. White Pine County
PERMIT NO. (Issued by Water Resources) 50-A (Parcel No.) (Subdivision Name)

3. WORK PERFORMED
☒ New Well ☐ Replace ☐ Recondition
☐ Deepen ☐ Abandon ☐ Other

4. PROPOSED USE
☒ Domestic ☐ Irrigation ☐ Test
☐ Municipal/Industrial ☐ Monitor ☐ Stock

5. WELL TYPE
☐ Cable ☒ Rotary ☐ RVC
☐ Air ☐ Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Gravel		5	10	5
Clay & Gravel		10	20	10
Gravel		20	65	45
Clay & Gravel		65	110	45
Clay		110	115	5
Water Bearing Gravel	x	115	120	5
Clay & Gravel		120	140	20
Water Bearing Gravel	x	140	145	5
Clay & Gravel		145	155	10
Water Bearing Gravel	x	155	175	20
Clay		175	183	8

'95 MAY -3 A11:38
RECEIVED
STATE ENGINEERS OFFICE

Date started October 6, 19 94
Date completed October 10, 19 94

7. WELL TEST DATA

TEST METHOD: ☐ Bailer ☐ Pump ☒ Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
300	105	1

8. WELL CONSTRUCTION
Depth Drilled 183 Feet Depth Cased 183 Feet

HOLE DIAMETER (BIT SIZE)

		From	To
12¼ Inches		0 Feet	183 Feet
Inches		Feet	Feet
Inches		Feet	Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
8 5/8"	16.94	.188	0	183

Perforations:
Type perforation Factory
Size perforation 1/8" x 2½" 8 rows
From 61 feet to 183 feet
From feet to feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: ☒ Yes ☐ No
Depth of Seal 50 ft.
Placement Method: ☐ Pumped ☒ Poured
Seal Type: ☐ Neat Cement ☒ Cement Grout ☐ Concrete Grout

Gravel Packed: ☒ Yes ☐ No
From 50 feet to 183 feet

9. WATER LEVEL
Static water level 75 feet below land surface
Artesian flow G.P.M. P.S.I.
Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Christiansen Drilling, Inc. (Contractor)
Address 557 Ely Avenue (Contractor)
Ely, NV 89301
Nevada contractor's license number issued by the State Contractor's Board 14790
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
Signed Jerald D. Christiansen (By driller performing actual drilling on site or contractor)
Date April 27, 1995

(Rev. 3-91) USE ADDITIONAL SHEETS IF NECESSARY (O)-627