

Log No. _____
 Permit No. _____
 Basin. 179

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 24649

1. OWNER Thomas R. Sanders ADDRESS AT WELL LOCATION Approximately 5 miles north of Ely
 MAILING ADDRESS P.O. Box 150433
E. Ely, NV 89315

2. LOCATION NE 1/4 NE 1/4 Sec. 36 T. 17 N&S R. 63 E. White Pine County
 PERMIT NO. 55203 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE Domestic Municipal/Industrial Irrigation Monitor Test Stock
 5. WELL TYPE Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Sand & Gravel		0	50	50
Course Gravel		50	65	15
Sand & Gravel		65	70	5
Course Gravel		70	110	40
Water Bearing Sand & Gravel	x	110	120	10
Clay & Gravel		120	155	35
Water Bearing Sand & Gravel	x	155	165	10
Clay & Gravel		165	200	35
Clay		200	245	45

8. WELL CONSTRUCTION
 Depth Drilled 245 Feet Depth Cased 245 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 245 Feet
14 1/4 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
10 3/4	28.04	250	0	245

Perforations:
 Type perforation Factory
 Size perforation 3/16" x 2 1/2" 10 rows
 From 52 feet to 224 feet
 From 224 feet to 245 feet Blank
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: Neat Cement Cement Grout Concrete Grout
 Depth of Seal 50
 Placement Method: Pumped Poured
 Gravel Packed: Yes No
 From 50 feet to 245 feet

9. WATER LEVEL
 Static water level 102 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started August 10, 1994
 Date completed August 23, 1994

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
110	138	2

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, NV 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
 Signed Jarrod D. Christiansen
 By driller performing actual drilling on site or contractor
 Date October 25, 1994