

OFFICE USE ONLY
 Log No. 30215
 Permit No. 17
 Basin. T

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 28875

1. OWNER Eric Williams ADDRESS AT WELL LOCATION 5 miles north of Ely
 MAILING ADDRESS 604 Murry Street
Ely, Nv 89301

2. LOCATION SE 1/4 SW 1/4 Sec 14 T 17 N&R 63 E White Pine County
 PERMIT NO. 05-581-64 Lot 6 Cross Timbers
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other.....
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC
 Air Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil		0	5	5
Gravel		5	25	20
Clay & Gravel		25	55	30
Water Bearing Gravel	x	55	70	15
Clay & Gravel		70	95	25
Water Bearing Gravel	x	95	115	20
Clay & Gravel		115	145	30
Water Bearing Sand & Gravel	x	145	150	5
Clay		150	160	10

8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet
 HOLE DIAMETER (BIT SIZE)
 From To
10 Inches 0 Feet 160 Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	160

Perforations:
 Type perforation Factory
 Size perforation 1/8" x 2 1/2" 6 rows
 From 60 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 160 feet

9. WATER LEVEL
 Static water level 55 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc.
 Address 557 Ely Avenue
Ely, NV 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641
 Signed Arnold D. Christiansen
 By driller performing actual drilling on site or contractor
 Date October 16, 1995

Date started October 5, 19 95
 Date completed October 7, 19 95

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
150	95	1

RECEIVED
 95 OCT 23 AM 11:19
 STATE ENGINEERS OFFICE