

OFFICE USE ONLY  
 Log No. 74821  
 Permit No. 1779  
 Basin 1779  
 NOTICE OF INTENT NO. 39994

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

1. OWNER Glenn Hammock ADDRESS AT WELL LOCATION Smith Valley  
 MAILING ADDRESS 561 Campton St. (Hercules Gap)  
Ely, NV 89301  
 2. LOCATION NE 1/4 NW 1/4 Sec 8 T 17 N 8 R 63 E White Pine County  
 PERMIT NO. APN 5-620-13 Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED  
 New Well  Replace  Recondition  
 Deepen  Abandon  Other.....  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  
 Municipal/Industrial  Monitor  Stock  
 5. WELL TYPE  
 Cable  Rotary  RVC  
 Air  Other.....

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Sand & Gravel		5	10	5
Sand & Course Gravel		10	30	20
Sand & Gravel		30	35	5
Clay & Gravel		35	45	10
Sand & Gravel		45	60	15
Clay		60	85	25
Clay & Gravel	x	85	95	10
Clay		95	110	15
Clay & Course Gravel	x	110	120	10
Clay		120	140	20
Clay & Gravel		140	160	20
Clay		160	200	40

8. WELL CONSTRUCTION  
 Depth Drilled 200 Feet Depth Cased 200 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 0 Feet 200 Feet  
 Inches Feet Feet  
 Inches Feet Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	200

Perforations:  
 Type perforation Factory  
 Size perforation 1 7/8 x 2 1/2 6 rows  
 From 80 feet to 200 feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet  
 From.....feet to.....feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50  Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 200 feet

9. WATER LEVEL  
 Static water level 81 feet below land surface  
 Artesian flow.....G.P.M.....P.S.I.  
 Water temperature cold °F Quality good

Date started January 19, 1999  
 Date completed January 26, 1999

7. WELL TEST DATA

TEST METHOD:  Bailer  Pump  Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
35	114	1 1/2

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Christiansen Drilling, Inc. Contractor  
 Address 557 Ely Avenue Contractor  
Ely, Nevada 89301  
 Nevada contractor's license number issued by the State Contractor's Board 14790  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793  
 Signed Rick Lewis By Jessie D. Christiansen  
 By driller performing actual drilling on site or contractor  
 Date February 3, 1999

RECEIVED  
 99 FEB -8 AM 10:59  
 STATE ENGINEERS OFFICE