

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.348

Log No. 76579  
 Permit No. \_\_\_\_\_  
 Basin. 179

PRINT OR TYPE ONLY  
 DO NOT WRITE ON BACK

NOTICE OF INTENT NO. 39998

1. OWNER N.D.O.T. ADDRESS AT WELL LOCATION 5 miles north of Ely (McGill flat gravel pit)  
 MAILING ADDRESS 1263 S. Stewart Street Carson City, NV 89712

2. LOCATION SE 1/4 NE 1/4 Sec. 26 T. 17 N&R. 63 E. White Pine County  
 PERMIT NO. C-194 Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_  
 Waiver

3. WORK PERFORMED  
 New Well  Replace  Recondition  Deepen  Abandon  Other \_\_\_\_\_  
 4. PROPOSED USE  
 Domestic  Irrigation  Test  Monitor  Stock  
 ~~Municipal~~ Industrial

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	2	2
Sand & Gravel		2	10	8
Sand & Large Gravel	x	10	25	15
Sand & Small Gravel		25	40	15
Sand & Gravel		40	60	20
Course Gravel	x	60	65	5
Sand & Gravel		65	120	55
Brown Clay & Gravel		120	140	20
Course Gravel	x	140	145	5
Brown Clay & Gravel		145	160	15
Brown Clay		160	182	22

8. WELL CONSTRUCTION  
 Depth Drilled 182 Feet Depth Cased 182 Feet  
 HOLE DIAMETER (BIT SIZE)  
 From 10 Inches To 182 Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet  
 \_\_\_\_\_ Inches \_\_\_\_\_ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	12.92	.188	0	182

Perforations:  
 Type perforation Factory  
 Size perforation 1/8" x 2 1/2" 6 rows  
 From 81 feet to 182 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

Surface Seal:  Yes  No Seal Type:  
 Depth of Seal 50 \_\_\_\_\_  
 Neat Cement  
 Placement Method:  Pumped  Cement Grout  
 Poured  Concrete Grout  
 Gravel Packed:  Yes  No  
 From 50 feet to 182 feet

9. WATER LEVEL  
 Static water level 20 feet below land surface  
 Artesian flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature cold °F Quality good

10. DRILLER'S CERTIFICATION  
 This well was drilled under my supervision and the report is true to the best of my knowledge.  
 Name Christiansen Drilling, Inc. Contractor  
 Address 557 Ely Avenue Contractor  
Ely, NV 89301  
 Nevada contractor's license number 14790 issued by the State Contractor's Board  
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 641  
 Signed Jensold D. Christiansen  
 By driller performing actual drilling on site or contractor  
 Date May 25, 1999

Date started May 15, 1999.  
 Date completed May 16, 1999.

7. WELL TEST DATA

TEST METHOD:	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<input type="checkbox"/> Bailer <input type="checkbox"/> Pump <input checked="" type="checkbox"/> Air Lift	<u>175</u>	<u>140</u>	<u>1 1/2</u>

RECEIVED  
 99 MAY 28 AM 11:04  
 STATE ENGINEERS OFFICE