

OFFICE USE ONLY
 Log No. 84071
 Permit No. _____
 Basin. 17A
 4592

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. _____

1. OWNER Walter Leineke ADDRESS AT WELL LOCATION 655 West 244 North Street
 MAILING ADDRESS PO Box 971
Reno, NV 89504

2. LOCATION SE 1/4 NE 1/4 Sec. 21 T 17 N R 63 E White Pine County
Lot 99 APN 5-601-25 Cross Timbers

PERMIT NO. _____ Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	4	4
Sand & Gravel		4	20	16
Clay & Gravel		20	50	30
Sand & Gravel		50	70	20
Clay & Gravel		70	95	25
Clay		95	115	20
Clay with water bearing sand & Gravel Stringers	X	115	130	15
Clay		130	155	25
Clay with water bearing sand & Gravel Stringers	X	155	170	15
Clay		170	181	11

8. WELL CONSTRUCTION
 Depth Drilled 181 Feet Depth Cased 181 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 181 Feet
10-5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	181

Perforations:
 Type perforation Factory
 Size perforation 1/8" X 2 1/2" 6 Rows
 From 100 feet to 181 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 50 Ft. Neat Cement
 Placement Method: Pumped Cement Grout
 Poured Concrete Grout

Gravel Packed: Yes No
 From 50 feet to 181 feet

9. WATER LEVEL
 Static water level 113 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

Date started July 12, 2001
 Date completed July 16, 2001

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
25	57	1

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc. Contractor
 Address 557 Ely Avenue Contractor
Ely, Nevada 89301
 Nevada contractor's license number issued by the State Contractor's Board 14790
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1793
 Signed Rich Lewis By Jarrod D. Christiansen
 By driller performing actual drilling on site or contractor
 Date July 19, 2001