

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 45796
5 Miles North of Ely

1. OWNER Ronald Cudney ADDRESS AT WELL LOCATION _____
 MAILING ADDRESS 1365 N. Celia Way _____
Layton, Utah 84041 _____
 2. LOCATION SE 1/4 SE 1/4 Sec. 15 T. 17 N. & R. 63 E. White Pine County
 PERMIT NO. Lot 50B APN 5-571-58 Cross Timbers _____
Issued by Water Resources Parcel No. Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other _____

4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	5	5
Clay & Gravel		5	15	10
Sand & Gravel		15	40	25
Gravel		40	50	10
Clay & Gravel		50	70	20
Water Bearing Sand & Gravel with Clay Seams	X	70	100	30
Sand		100	110	10
Clay & Course Gravel		110	125	15
Course Gravel	X	125	130	5
Clay		130	150	20
Clay & Course Gravel		150	161	11

8. WELL CONSTRUCTION
 Depth Drilled 161 Feet Depth Cased 161 Feet

HOLE DIAMETER (BIT SIZE)
 From 0 Feet To 161 Feet
10 5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6-5/8	12.92	.188	0	161

Perforations: Factory
 Type perforation _____
 Size perforation 1/8" x 2" 6 Rows
 From 80 feet to 161 feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type: _____
 Depth of Seal 50 Feet Neat Cement
 Placement Method: Pumped Poured Cement Grout
 Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 161 feet

9. WATER LEVEL
 Static water level 85 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature Cold °F Quality Good

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Christiansen Drilling, Inc.
 Contractor
 Address 557 Ely Avenue
 Contractor
Ely, Nevada 89301
 Nevada contractor's license number 14790
 issued by the State Contractor's Board
 Nevada driller's license number issued by the 1793
 Division of Water Resources, the on-site driller
 Signed Rick Lewis By Gerald D. Christiansen
 By driller performing actual drilling on site or contractor
 Date September 4, 2001

Date started August 27, 2001
 Date completed August 31, 2001

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>50</u>	<u>70</u>	<u>2</u>