



**WELL DRILLERS REPORT**

Please complete this form in its entirety

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 2102

OWNER Keith Whipple ADDRESS AT WELL LOCATION \_\_\_\_\_  
 MAILING ADDRESS Hiko NV 89001

2. LOCATION N.W. 1/4, NW 1/4 Sec. 14 T. 45 N/S R. 60 E Lincoln County

PERMIT NO. \_\_\_\_\_ Issued by Water Resources Parcel No. \_\_\_\_\_ Subdivision Name \_\_\_\_\_

3. Replacement well, approx. 50' S  
 TYPE OF WORK PROPOSED USE 5. TYPE WELL  
 New Well  Recondition  Domestic  Irrigation  Test  Cable  Rotary   
 Deepen  Other  Municipal  Industrial  Stock  Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
<u>gravel</u>		<u>0</u>	<u>52</u>	<u>52</u>
<u>Brown clay</u>		<u>52</u>	<u>69</u>	<u>17</u>
<u>Hard panned gravel</u>		<u>69</u>	<u>72</u>	<u>3</u>
<u>sand &amp; gravel</u>		<u>72</u>	<u>95</u>	<u>23</u>
<u>coarse gravel</u>		<u>95</u>	<u>110</u>	<u>15</u>
<u>layers, sand, gravel</u>		<u>110</u>	<u>164</u>	<u>54</u>
<u>cemented gravel &amp; clay</u>		<u>164</u>	<u>166</u>	<u>2</u>
<u>clay</u>		<u>166</u>	<u>193</u>	<u>27</u>

8. 16" to 110" WELL CONSTRUCTION

Diameter hole 17" to 110" to 193' inches Total depth 193 feet  
 Casing record 12" to 163' wall  
 Weight per foot 8" to 193' thickness 1.88 wall

Diameter	From	To
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes  No  Type Concrete  
 Depth of seal 50' feet  
 Gravel packed: Yes  No   
 Gravel packed from 50' feet to 160' feet

Perforations:  
 Type perforation Truck  
 Size perforation 1/4 x 12  
 From 50 feet to 193 feet  
 From \_\_\_\_\_ feet to \_\_\_\_\_ feet

**RECEIVED**

MAR 25 1986

DIV. of Water Resources  
 Branch Office - Las Vegas, NV

9. WATER LEVEL

Static water level 71 feet below land surface  
 Flow \_\_\_\_\_ G.P.M. \_\_\_\_\_ P.S.I.  
 Water temperature Cold F. Quality good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Darell H. Free Contractor

Address Box 122 Pahrump, NV Contractor

Nevada contractor's license number 3422

Nevada contractor's drillers number 30

Wayne Lister  
 Nevada driller's license number 1441 Actual Driller

Signed Darell H. Free Contractor

Date 3/19/86

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump
<u>1760</u>	<u>300</u>	<u>50'</u>	<u>24 hours</u>
_____	_____	_____	_____
_____	_____	_____	_____

BAILER TEST

G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours  
 G.P.M. \_\_\_\_\_ Draw down \_\_\_\_\_ feet \_\_\_\_\_ hours