WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

PRINT OR TYPE ONLY
DO NOT WRITE ON BACK

STATE OF NEVADA
DIVISION OF WATER RESOURCES

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

OFFICE USE ONLY
Log No. 52879
Permit No.
Basin 209

NOTICE OF INTENT NO. 6859

1. OWNER Phillip Spencer
MAILING ADDRESS P.O. Box 1 Hiko Nev 89017
ADDRESS AT WELL LOCATION Mile Marker # 5 SR 318 East Side Hiko Nev. 89017

2. LOCATION S/W ¼ S/W ¼ Sec. 14 T. 4 N/S R. 60 E. Lincoln County
PERMIT NO. 0 (Issued by Water Resources) | Parcel No. 6 | Subdivision Name

3. WORK PERFORMED
[X] New Well [ ] Replace [ ] Recondition
[ ] Deepen [ ] Abandon [ ] Other

4. PROPOSED USE
[X] Domestic [ ] Irrigation [ ] Test
[ ] Municipal/Industrial [ ] Monitor [ ] Stock

5. WELL TYPE
[ ] Cable [X] Rotary [ ] RVC
[ ] Air [ ] Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
Top Soil		0	32	32
Sand - Boulders		32	80	48
Clay - Sand		80	86	86
Sand - gravel - Boulders	X	86	100	14
Clay		100	119	19
gravel - Sand	X	119	128	9
Clay		128	130	2
TD 130'				

Date started 7-14-96, 19
Date completed 7-16-96, 19

7. WELL TEST DATA
TEST METHOD: [X] Bailer [ ] Pump [ ] Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
14	2	3

8. WELL CONSTRUCTION
Depth Drilled 130 Feet Depth Cased 130 Feet

HOLE DIAMETER (BIT SIZE)

		From		To	
10 5/8	Inches	0	Feet	130	Feet
	Inches		Feet		Feet
	Inches		Feet		Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
6 5/8	0	.188	0	130

Perforations:
Type perforation Torch cut
Size perforation 1/8" x 6"
From 70 feet to 100 feet
From 120 feet to 130 feet
From feet to feet
From feet to feet
From feet to feet

Surface Seal: [X] Yes [ ] No
Depth of Seal 50
Placement Method: [ ] Pumped [X] Poured
Seal Type: [ ] Neat Cement [ ] Cement Grout [X] Concrete Grout

Gravel Packed: [X] Yes [ ] No
From 50 feet to 130 feet

9. WATER LEVEL
Static water level 81 feet below land surface
Artesian flow 0 G.P.M. 0 P.S.I.
Water temperature cold °F Quality poor

10. DRILLER'S CERTIFICATION
This well was drilled under my supervision and the report is true to the best of my knowledge.
Name Davis Drilling (Contractor)
Address P.O. Box 54 (Contractor)
Hiko Nev. 89017
Nevada contractor's license number issued by the State Contractor's Board 0028966
Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
Signed Mike Davis (By driller performing actual drilling on site or contractor)
Date 7-19-96