

STATE OF NEVADA
 DIVISION OF WATER RESOURCES

OFFICE USE ONLY
 Log No. 82283
 Permit No. _____
 Basin 209

PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 19580

1. OWNER John Scott
 MAILING ADDRESS HC 61 Box 48 Hiko NV 89017
 ADDRESS AT WELL LOCATION 5R 318 Hiko NV East side of Hwy
 2. LOCATION S/E 1/4 N/E 1/4 Sec 34 T 4 N 60 E Lincoln
 PERMIT NO. 11-090-20 Issued by Water Resources Parcel No. _____ Subdivision Name _____

3. WORK PERFORMED
 New Well Replace Recondition Deepen Abandon Other _____
 4. PROPOSED USE
 Domestic Irrigation Test Municipal/Industrial Monitor Stock
 5. WELL TYPE
 Cable Rotary RVC Air Other _____

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Top Soil - Boulders		0	12	12
sand - boulders		12	85	73
cemented Gravel		85	92	7
gravel - boulders	X	92	125	33
Hard Rock		125	131	6
sand - Gravel - boulders	X	131	164	33
Hard Rock		164	167	3

8. WELL CONSTRUCTION
 Depth Drilled 167 Feet Depth Cased 167 Feet
 HOLE DIAMETER (BIT SIZE)
 From 0 To 167
10 5/8 Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet
 _____ Inches _____ Feet _____ Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>6 1/2</u>		<u>sch 40</u>	<u>0</u>	<u>167</u>

Perforations:
 Type perforation saw cut
 Size perforation 1 1/2" x 6"
 From 67' feet to 87' feet
 From 107' feet to 127' feet
 From 147' feet to 167' feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 Surface Seal: Yes No Seal Type:
 Depth of Seal 50 _____
 Neat Cement
 Placement Method: Pumped Poured Cement Grout Concrete Grout
 Gravel Packed: Yes No
 From 50 feet to 167 feet

9. WATER LEVEL
 Static water level 67 feet below land surface
 Artesian flow _____ G.P.M. _____ P.S.I.
 Water temperature cool °F Quality fair

Date started 1-2-2001, 19_____
 Date completed 1-3-2001, 19_____
 7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>19</u>	<u>9</u>	<u>4</u>

10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name Davis Drilling and Pumps Contractor
 Address HC 61 Box 54 Hiko NV 89017 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 0028966
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 1-3-2001

