

OFFICE USE ONLY
 Log No. 61850
 Permit No. 56654
 Basin 220



PRINT OR TYPE ONLY
 DO NOT WRITE ON BACK

WELL DRILLER'S REPORT

Please complete this form in its entirety in accordance with NRS 534.170 and NAC 534.340

NOTICE OF INTENT NO. 12206

1. OWNER Kevin Street ADDRESS AT WELL LOCATION 2120 West Bowman
 MAILING ADDRESS P.O. Box 1457 Overton NV. Legandale NV.
89040

2. LOCATION N/W 1/4 S/W 1/4 Sec. 15 T. 15 N. R. 67 E. Clark County
 PERMIT NO. 56654 730-370-007-97 Subdivision Name

3. WORK PERFORMED
 New Well Replace Recondition
 Deepen Abandon Other


4. PROPOSED USE
 Domestic Irrigation Test
 Municipal/Industrial Monitor Stock

5. WELL TYPE
 Cable Rotary RVC
 Air Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thickness
TOP Soil		0	15	15
Clay-sand		15	68	53
Clay-boulders-gravel		68	79	11
clay		79	111	32
Clay-gravel	X	111	125	14
Fractured Rock	X	125	160	35

TD 160'



8. WELL CONSTRUCTION
 Depth Drilled 160 Feet Depth Cased 160 Feet

HOLE DIAMETER (BIT SIZE)

From	To
<u>15 1/2</u> Inches	<u>0</u> Feet <u>130</u> Feet
<u>12 1/4</u> Inches	<u>130</u> Feet <u>160</u> Feet

CASING SCHEDULE

Size O.D. (Inches)	Weight/Ft. (Pounds)	Wall Thickness (Inches)	From (Feet)	To (Feet)
<u>8 5/8</u>	<u>2</u>	<u>.188</u>	<u>0</u>	<u>160</u>

Perforations:
 Type perforation Rotary
 Size perforation 1 1/8" x 3"
 From 100 feet to 160 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Surface Seal: Yes No Seal Type:
 Depth of Seal 100'
 Neat Cement
 Cement Grout
 Concrete Grout
 Placement Method: Pumped
 Poured
 Gravel Packed: Yes No
 From 100 feet to 160 feet

9. WATER LEVEL
 Static water level 35 feet below land surface
 Artesian flow 0 G.P.M. P.S.
 Water temperature cold °F Quality good



10. DRILLER'S CERTIFICATION
 This well was drilled under my supervision and the report is true to the best of my knowledge.

Name Davis Drilling Contractor
 Address PO Box 54 Contractor
Hiko NV 89017
 Nevada contractor's license number issued by the State Contractor's Board 0078966
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 1191
 Signed Mike Davis
 By driller performing actual drilling on site or contractor
 Date 2-10-97

7. WELL TEST DATA

TEST METHOD: Bailer Pump Air Lift

TEST METHOD	G.P.M.	Draw Down (Feet Below Static)	Time (Hours)
<u>air lift</u>	<u>45</u>	<u>0</u>	<u>5</u>