WHITE—DIVISION OF WATER RESOURCES
CANARY—CLIENT'S COPY
PINK—WELL DRILLER'S COPY

STATE OF NEVADA
DIVISION OF WATER RESOURCES

# WELL DRILLERS REPORT

Please complete this form in its entirety

OFFICE USE ONLY
Log No. 26774
Permit No.
Basin 161

In Book

PRINT OR TYPE ONLY

NOTICE OF INTENT NO. 1951

1. OWNER James Fisher Jr
MAILING ADDRESS P.O. Box 455
Indian Springs NV 89018

ADDRESS AT WELL LOCATION Indian Springs

2. LOCATION ¼ ¼ Sec. 48C T. 165 N/S R. 56 E. Clark County

PERMIT NO. (Issued by Water Resources) 1196780 #2 (Parcel No.) (Subdivision Name)

3. TYPE OF WORK: New Well ☒ Recondition ☐ Deepen ☐ Other ☐

4. PROPOSED USE: Domestic ☒ Irrigation ☐ Test ☐ Municipal ☐ Industrial ☐ Stock ☐

5. TYPE WELL: Cable ☐ Rotary ☒ Other ☐

6. LITHOLOGIC LOG

| Material | Water Strata | From | To | Thickness |
|---|---|---|---|---|
| Top Soil | | 0 | 2 | 2 |
| Blue Clay | | 2 | 14 | 12 |
| Cemented Sand & gravel | | 14 | 18 | 4 |
| Brown Clay | | 18 | 26 | 8 |
| Loose Black Sand | WB | 26 | 30 | 4 |
| Clay | | 30 | 36 | 6 |
| Cemented Sand | | 36 | 40 | 4 |
| Sand | WB | 40 | 46 | 6 |
| Cemented Sand | | 46 | 48 | 2 |
| Clay Sand & gravel | WB | 48 | 66 | 18 |
| Cemented Sand | | 66 | 71 | 5 |
| Sand | WB | 71 | 74 | 3 |
| Cemented Sand | | 74 | 90 | 24 |
| Loose Sand & gravel | WB | 90 | 110 | 20 |
| Cemented gravel | | 110 | 112 | 2 |
| Lime | | 112 | 142 | 30 |
| gravel | WB | 142 | 152 | 10 |
| Cement gravel | | 152 | 162 | 10 |

RECEIVED
MAR 1 1985
Div. of Water Resources
Branch Office - Las Vegas, NV

Date started 2-9, 1985
Date completed 2-13, 1985

7. WELL TEST DATA

| Pump RPM | G.P.M. | Draw Down | After Hours Pump |
|---|---|---|---|
| | No test. | | |

BAILER TEST

G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours
G.P.M. ..... Draw down ..... feet ..... hours

8. WELL CONSTRUCTION

Diameter hole 12¼ inches Total depth 162 feet
Casing record 163 Ft 8" Casing
Weight per foot 14 lb Thickness .1956

| Diameter | From | To |
|---|---|---|
| 8 inches | -1 feet | 162 feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |
| inches | feet | feet |

Surface seal: Yes ☒ No ☐ Type Cement
Depth of seal 50 ft. feet
Gravel packed: Yes ☒ No ☐
Gravel packed from 50 feet to 162 feet

Perforations:
Type perforation Metal Saw
Size perforation ⅛" by 3"
From 96 feet to 118 feet
From 140 feet to 162 feet
From ..... feet to ..... feet
From ..... feet to ..... feet
From ..... feet to ..... feet

9. WATER LEVEL

Static water level 11 feet below land surface
Flow ..... G.P.M. ..... P.S.I.
Water temperature 69 °F. Quality Good

10. DRILLERS CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.

Name St H Drilling (Contractor)
Address 3312 Thom Blvd. LVNV (Contractor)
Nevada contractor's license number 0022059
Nevada contractor's drillers number
Nevada driller's license number 1426 (Actual Driller)
Signed Steven G. Hamel (Contractor)
Date 2-13-85

USE ADDITIONAL SHEETS IF NECESSARY

(Rev. 6-81) O-627 CR434