

OFFICE USE ONLY
 Log No. 34555
 Permit No. 55269
 Basin 215
 NOTICE OF INTENT No. 3543

EBP-2
 PRINT OR TYPE ONLY

WELL DRILLER'S REPORT
 Please complete this form in its entirety

1. OWNER Bonneville Energy ADDRESS AT WELL LOCATION Gypsum Wash
 MAILING ADDRESS c/o Mifflin & Associates 89120
2700 E. Susnet, Suite C-25, Las Vegas, NV
 2. LOCATION NE SE SE 1/4 Sec 13 T. 19 SR 63 E. Clark County
 PERMIT NO. 55269 Issued by Water Resources Parcel No. Subdivision Name

3. TYPE OF WORK
 New Well Recondition
 Deepen Other
 4. PROPOSED USE
 Domestic Irrigation Test
 Municipal Industrial Stock
 5. TYPE WELL
 Cable Rotary
 Other

6. LITHOLOGIC LOG

Material	Water Strata	From	To	Thick-ness
Cemented limestone		0	325	325
Clay with limestone		325	430	105
Frac. limestone w/iron oxide & travertine		430	475	45
Cem. quartz & limestone		475	575	100
Quartz, lt. grey limestone & clayey limestone		575	630	55
Limestone, dolomite w/red to brn. sandstone		630	780	150
Fractured w/travertine		780	800	20
Lt. to dk. grey limestone		800	1214	414

8. WELL CONSTRUCTION

Diameter 17 inches Total depth 1,214 feet
12 inches to 997'
12 inches to 1,214

Casing record
 Weight per foot .279 Thickness .279

Diameter	From	To
12 1/8 inches	+1 feet	997 feet
8 1/8 inches	974 feet	1,214 feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet
_____ inches	_____ feet	_____ feet

Surface seal: Yes No Type Cement
 Depth of seal 60 feet
 Gravel packed: Yes No
 Gravel packed from _____ feet to _____ feet

Perforations: (8" single cut -
 Type perforation Mill slots 12" double cut)
 Size perforation 1/2 x 2 1/2"
 From 755 feet to 1,214 feet
 From 12" - 755 feet to 960 feet
 From 8" - 974 feet to 1,214 feet
 From _____ feet to _____ feet
 From _____ feet to _____ feet

Date started March 27, 1990
 Date completed June 12, 1990

7. WELL TEST DATA

Pump RPM	G.P.M.	Draw Down	After Hours Pump

BAILER TEST

G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours
 G.P.M. _____ Draw down _____ feet _____ hours

9. WATER LEVEL

Static water level 575 feet below land surface
 Flow _____ G.P.M. _____ P.S.I.
 Water temperature _____ °F Quality _____

10. DRILLER'S CERTIFICATION

This well was drilled under my supervision and the report is true to the best of my knowledge.
 Name THOMPSON DRILLING CO., INC.
4185 W. Harmon Contractor
 Address Las Vegas, NV 89103 Contractor
 Nevada contractor's license number issued by the State Contractor's Board 4286A
 Nevada contractor's driller's number issued by the Division of Water Resources 290
 Nevada driller's license number issued by the Division of Water Resources, the on-site driller 856
 Signed Richard Thompson
 By driller performing actual drilling on site or contractor
 Date October 4, 1990