

IN THE OFFICE OF THE STATE ENGINEER
OF THE STATE OF NEVADA

O R D E R

Park Avenue Water Users Association
5640 North Park Street
Las Vegas, NV 89129
Certified Mail No. P 680 337 670

The records of the office of the State Engineer indicate that you are the owner of a well located in the SW1/4 SE1/4 of Section 30, T.19S., R.60E., M.D.B.&M., Clark County, Nevada, as further described under Permit No. 51932.

This permit was issued on March 31, 1989, for quasi-municipal purposes for eight single-family residences with a place of use described as being the W1/2 SE1/4 SW1/4 SE1/4 of Section 30, T.19S., R.60E., with a diversion rate and annual duty not to exceed 0.25 c.f.s. and 2.92 million gallons respectively. Site investigations have revealed consistent water withdrawal exceeding the permitted amount and an additional residence being served outside the place of use specified by the subject permit.

The current use of this well is not in accordance with the terms and conditions of the permit. Therefore you, and each of you, is ordered, under the authority of 533.325 and 534.080 of Nevada Revised Statutes, to reduce the withdrawal of water from the well to the permitted amount and to limit the place of use to the location authorized under Permit No. 51932. Full compliance with this order will be expected within 30 days of this date.


R. MICHAEL TURNIPSEED, P.E.
State Engineer

Dated at Carson City, Nevada,

this 5th day of April, 1991.

Southern Nevada Branch Office