

OFFICE OF STATE ENGINEER

REF: 10152

Mr. Frank Ellis,
2219 Fremont Street,
Las Vegas, Nevada.

ORDER

Dear Sir:

This letter is written as an Office Order of the State Engineer to advise you that the well on your property at 2219 Fremont Street, drilled under Permit 10152, must either be repaired or plugged.

The well was drilled about 1938 and the log shows that there was only sixty (60) feet of casing placed in the well. The log does not show that the casing was properly sealed with concrete. If you intend to use water from this well, it will be necessary for you to case the well to the bottom and to seal off all surface water.


If you do not intend to use the well you should have it plugged from the bottom with cement or drilling mud.

Please contact Mr. Francis Thorne, Las Vegas Artesian Well Supervisor, whose office is located in the new State Office Building on Bonanza Road, and whose phone number is Dudley-2-6070, Extension 9, regarding your plans. You should submit your plans for correcting this well to Mr. Thorne and obtain his approval within fifteen (15) days of the date of this Order.

Very truly yours,

HUGH A. SHAMBERGER
State Engineer

By



EDMUND NUTH
Assistant State Engineer

EN:at

Certified Mail

Dated January 25, 1956.