WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

X

Log No. 1308
Rec. 6/7 1950
Well No.
Permit No.
Do not fill in

Owner Joe Nishikita Driller Jesse J Harrison

Address Gardnerville, Nev. Address Box 41 Carson City Lic. No. 6

Location of well: NE 1/4 NE 1/4 Sec. 10, T. 15 N/S, R 20 E, in Armsby County

or about 50' N of the N.E. Cor of House, on left side of Dayton Rd. Old Empire

Water will be used for domestic Total depth of well 84'

Size of drilled hole 22" Weight of casing per linear foot 10.088

Thickness of casing .237 Temp. of water Cold

Diameter and length of casing 4" X 81'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface 14'

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well June 3rd 1950 Date of completion of well June 5th 1950

Type of well rig Rotary Hydraulic

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	4	4	top soil
4	7	3	Round rocks 6" diam
7	10	3	sand
10	17	7	Hard pan
17	20	3	fine Red sand
20	30	10	Gypsite
30	37	7	Blue Hard pan very Hard
37	47	10	fine Brown sand
47	53	6	Gypsite
53	55	2	fine brown sand
55	57	2	Blue Clay
57	81	14	sand Gravel & Boulders
81	84	3	Hard pan Greenish Color

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 57 to 81 ft.

Other aquifers 7 to 10'
17 to 20'
37 to 47
53 to 55

First water at ..... feet.

Casing perforated

from 61 to 81 ft.

Size of perforations

3/16 x 10"

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
4"	0	81	81	New 4" standard Black Iron threaded casing Grand packed sealed off at 58' from surface to stop water from passing thru Blue Clay

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Test pumped at 500 gals per Hr.
3' drawdown rained back to 14' from surface
Immediately after pump stopped, water very clear
Do not know the quality of this water according to the formations. I would suggest the water be tested after being pumped thoroughly.

WELL DRILLERS STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Juan J. Harrison
Well Driller

By .....

License No. 6

Dated June 2nd, 19 52

(Not to be filled in by Driller)