Log No. 1869
Rec. Feb 29 1952
Well No. 6 7 8
Permit No. 13708, 13709
Do not fill in 13709

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

25590
16938
25223

Golf Course (By transformer)

Owner: Wilbur Clarks Desert Inn. Driller: G.B.Rodgers E well

Address: Lasvegas Nev. Address: 3600 Polentino Lane Lic. No. 51

Location of well: SW ¼ NE ¼ Sec. 15, T. 21 N/S, R. 61 E, in Clark County

or Permit # 13709

Water will be used for: Recreational & Dom. Total depth of well: 440

Size of drilled hole: 200 20 in. 200 16 in. Weight of casing per linear foot: 24 16

Thickness of casing: 3/16 Temp. of water: 68

Diameter and length of casing: 200 ft. 16 in. 160 ft. of 10" liner
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface: 12/31/61 -12.64 ft.

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well: sept 18 1951 Date of completion of well: Nov 28 1951

Type of well rig: Spudder

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
00	8	8	s and & gravel
8	18	10	cement Gravel watter 18
18	30	12	white clay
30	60	30	brown clay
60	180	120	Layers Pink clay & rock
180	205	25	hard brown rock watter
205	260	55	layers of rock & clay
260	275	15	Hard lavender rock
275	380	105	layers of Pink clay & rock
380	410	30	cement gravel Poris watter
410	440	30	hard Lavender rock
			Finished 440

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 380 to 410 ft.

Other aquifers 18

180 205

First water at 18 feet.

Casing perforated

from 180 to 440 ft.

Size of perforations

½ x 4 in.

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
16	0	208		This well was gravel packed with 3/4" gravel from 160 ft 440 ft around the 10" liner to 16" wall with 15 yrds. of gravel
10	180	440		

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

The pump test showed approx. 400 G.P.M. with a 60 ft. draw down from the surface

WELL DRILLERS STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed [signature]
Well Driller

By.....

License No. 51

Dated.....19.....

(Not to be filled in by Driller)