Log No. 2127
Rec. Jan 12 1953
Well No.
Permit No. 14332
Do not fill in

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

copy

Owner Molasky Lewis + Rose Molasky Driller Sherlie Gribbs

Address Las Vegas, Nevada Address 5500 Paloma Lane Lic. No. 70

Location of well: SW 1/4 SW 1/4 Sec. 12, T 21 N/S, R 61 E, in Clark County

or

Water will be used for Guns - Municipal Total depth of well 235

Size of drilled hole 14 Inch Weight of casing per linear foot 22 lbs.

Thickness of casing 1/4 Temp. of water

Diameter and length of casing 8 Inch. ID or 8 5/8 OD 235ft. 8 Inch.
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface -45.00. 11/3/52 MP 1 1/4" outlet 10 above el.

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well Oct. 17, 1952 Date of completion of well Oct. 27, 1952

Type of well rig Spudder

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material	
0	5	5	Fill	
5	10	5	Caliche	
10	19	9	White Clay	
19	20	1	Gravel	Water
20	30	10	Hard rock	
30	60	30	Red clay	
60	68	8	White clay	
68	70	2	Gravel	water
70	80	10	Hard rock	
80	100	20	Red clay	
100	110	10	Hard rock	
110	160	50	Red clay	
160	165	5	Rock	
165	184	19	Red clay	
184	185	1	Gravel	Water
185	215	30	Hard rock	
215	217	2	Red clay	
217	229	12	Rock	
229	235	6	Red clay	

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 184 to 185 ft.

Other aquifers 28-30

19-20

First water at 19 feet.

Casing perforated

from 70 to 184 ft.

Size of perforations

5/32

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
[illegible]	0	[illegible]	[illegible]	5 Yards of gravel around 8 inch pipe to gravel back same and also 5 yards of grouting to cement off surface water

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailer tested well at the rate of 60 gallons of water per. Min. with the drawdown of 60 Ft. of surface.

Permit approved for .066 CFS. or 30 GPM

WELL DRILLERS STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Charlie Cribbs
Well Driller

By J. D. Rodgers

License No. 70

Dated Oct. 31, 1959

(Not to be filled in by Driller)