WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 2941
Rec. 5/10 1955
Well No.
Permit No. 15841
Do not fill in

Owner: Atacama Tarn Trailer Park ~~R.E. Wright, Jr. & F.A. Kuhnes~~ F.A. Mitchell
Address: 1955 E. College Avenue, Las Vegas, Nevada
Driller: Nevada Pump & Supply Company
Address: Las Vegas, Nevada Lic. No. 143

Location of well: SW SE ¼ NW ¼ Sec. 19, T. 20 N/S, R. 62 E, in Clark County

or Quasi Municipal PARCE# 140-19-203-015

Water will be used for Domestic Total depth of well 200 feet

Size of drilled hole 12" Weight of casing per linear foot 12 lbs.

Thickness of casing 10 gauge Temp. of water

Diameter and length of casing 8" x 200'
(Casing 12" in diameter and under give inside diameter: casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface 48 feet

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well April 11, 1955 Date of completion of well April 14, 1955

Type of well rig Cable Tools

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
	0	0	Top Soil
0	10	10	Sandy Clay
10	26	16	Hard packed sand
26	45	19	Sandy Red Clay
45	55	10	Fine sand-water bearing
55	78	23	Sandy Clay
78	85	7	Mushy soft sandy clay
85	91	6	Sandstone
91	105	14	Coarse Sand-Water bearing
105	115	10	Sticky Clay
115	125	10	Coarse Sand-Water bearing
125	145	20	Sticky Clay
145	158	13	Coarse Sand-Water bearing
158	172	14	Sticky tough clay
172	180	8	Coarse sand-Water bearing
180	188	8	Sticky Clay
188	195	7	Coarse Sand-Water bearing
195	200	5	Sticky Clay

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 188 to 195 ft.

Other aquifers 45 - 55
91 - 105
115-125
145-158
172-180

First water at 45 feet.

Casing perforated

from 110 to 200 ft.

Size of perforations

1/16" x 6"

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks" Seals, Grouting, Etc.
8"	0	200	200	50 feet of cement grout 150 feet of pea gravel fill

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

100 gpm at 56 feet pumping level

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed NEVADA PUMP & SUPPLY COMPANY
Well Driller

By [illegible]

License No. 103

Dated April 13, 1955

(Not to be filled in by Driller)