# WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 4291
Rec. Oct. 22 19 58
Well No.
Permit No.
Do not fill in

GORDON ELECTRIC P.O. Box 271

Owner GLEN GORDON Driller JESSE J. HARRISON

Address N. CARSON ST. HI-WAY 395 CARSON City Address HARRISON LANE CARSON City NEV. Lic. No. 6

Location of well: ____ ¼ ____ ¼ Sec. ____, T. 15 N/S, R 20 E, in ORMSBY County

or N. CARSON ST. HI-WAY 395 CONCRETE BLOCK HOUSE, REAR OF HOUSE

Water will be used for DOMESTIC PURPOSES Total depth of well 63'

Size of drilled hole 10" Weight of casing per linear foot 10.088 lbs

Thickness of casing 1/4" Temp. of water

Diameter and length of casing 4" X 63'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface AT SURFACE

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well Aug 19-58 Date of completion of well Aug 22nd 1958

Type of well rig

## LOG OF FORMATIONS

| From feet | To feet | Thickness feet | Type of material |
|---|---|---|---|
| 0 | 4 | 4 | HARD PAN |
| 4 | 14 | 10 | Decomposed Granite |
| 14 | 19 | 5 | hard pan |
| 19 | 28 | 9 | Decomposed Granite |
| 28 | 35 | 7 | hard pan |
| 35 | 45 | 10 | D G. sand |
| 45 | 50 | 5 | hard pan |
| 50 | 63 | 13 | D G. sand Coarse |

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 50 to 63 ft.

Other aquifers 19 to 28'
35' to 45'

46 14 small amount

First water at 4 feet.

Casing perforated
from 55 to 63 ft.

Size of perforations
3/16 X 6"
3 rows around, casing staggered
cut 6" skip 6"

919

LOG OF FORMATIONS—*Continued*

| From feet | To feet | Thickness | Type of material |
|---|---|---|---|
| | | | |

CASING RECORD

| Diam. casing | From feet | To feet | Length | "Remarks"—Seals, Grouting, Etc. |
|---|---|---|---|---|
| 4" | 0 | 63 | 63 | new standard Guage J & C. gravel packed to 55 ft. sealed off above 55 ft. |

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

1/2 hp. jet pump Installed
Pumped steady for 7 days & nights
5 ft draw down.
Good clear Water no sand,
Water soft.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Jesse J. Harrison
Well Driller

By

License No. 6

Dated Oct. 21st, 1958

(Not to be filled in by Driller)

1958 OCT 22 AM 11 32

STATE ENGINEER
OFFICE