Hood copy

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 4737
Rec. July 16 1959
Well No.
Permit No. 18018
Do not fill in

Owner Sunrise Motel--Mr. Jones Driller Effinger Drill & Pump Serv.

Address 3927 Las Vegas Blvd-South Address 5488 W. Duncan Dr. Lic. No. 212

Location of well NW ¼ SW ¼ Sec. 21, T21 N/S, R61 E, in Clark County

or 3927 Las Vegas Blvd. South

Water will be used for Commercial Refrigeration Total depth of well 200 Feet each

Size of drilled hole 10 Inch Weight of casing per linear foot

Thickness of casing 7 Guage Temp. of water

Diameter and length of casing 6" ID 200 feet and 6" X 200'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface 35' from top of casing

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well May 25, 1959 Date of completion of well June 8, 1959

Type of well rig "71 Speed Star"

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
			Pump Well
0	2	2	Concrete slab & fill
2	4	2	Gravel
4	16	12	Sandy Clay
16	20	4	Gravel
20	28	8	White Clay
28	30	2	Gravel (Water)
30	35	5	Clay
35	45	10	Gravel (Water)
45	90	45	Red Sandy Clay
90	120	30	Clay & Gravel
120	135	15	Gravel (Water)
135	160	25	Red Clay
160	175	15	Limestone
175	182	7	Gravel (Water)
182	200	18	Clay
			Return Well
0	25	25	Sandy Clay
25	30	5	Gravel
30	34	4	Gravel (Water)
34	45	11	Sand & Gravel (Water)
45	90	45	Red Sandy Clay

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from ..... to ..... ft.

Other aquifers

First water at ..... feet.

Casing perforated

from ..... to ..... ft.

Size of perforations

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material
90	120	30	Clay & Gravel
120	135	15	Gravel (Water)
135	160	25	Red Clay
160	175	15	Limestone
175	190	15	Gravel (Water)
190	200	10	Clay

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
6" ID	0	200	200	Cemented from 0 to 52 feet 6 yards of pea gravel 3 yards of cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Drill & Pump
Well Driller

By A F Effinger

License No. 212

Dated June 8, 19 59

(Not to be filled in by Driller)

1959 JUL 16 AM 9 24

ENGINEER

OFFICE