Need copy

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

THIS WELL PLUGGED BY DOUG SLAGLE 9-18-72
12 YD. PEA GRAVEL 1½ YD CEMENT.

Log No. 4788
Rec. Aug. 14 19 59
Well No.
Permit No. 24325
Do not fill in

Owner: Hollywood Vegas, Inc. Driller: Effinger Drill & Pump Serv.

Address: Address: 5468 W. Duncan Dr. Lic. No. 212

Location of well: NW ¼ NW ¼ Sec. 35, T 20 N/S, R 62 E, in Clark County

or Hollywood Blvd & Sloans Ave.

Water will be used for: Quasi-Municipal Total depth of well: 500 feet

Size of drilled hole: 26 inch Weight of casing per linear foot:

Thickness of casing: 3/4" & 7 Gauge Temp. of water:

Diameter and length of casing: 10"ID 230 feet 6"ID 280 feet
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure:

If nonflowing well give depth of standing water from surface: 92'

If flowing well describe control works:
(Type and size of valve, etc.)

Date of commencement of well: May 12, 1959 Date of completion of well: July 2, 1959

Type of well rig: "71 Speed Star"

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	15	15	Gravel
15	30	15	Clay & Gravel
30	110	80	Sandy Clay & Gravel
110	112	2	Sand (Water)
112	165	53	Clay
165	190	25	Sandy Clay
190	200	10	Sand (Water)
200	215	15	Sand Clay & Gravel
215	225	10	Sand & Gravel
225	250	25	Red Sandy Clay
250	265	15	Gravel (Water)
265	290	25	Clay
290	305	15	Sand & Gravel (Water)
305	345	40	Clay
345	420	75	Red Clay
420	435	15	Sandstone (Water)
435	478	43	Red Sandy Clay
478	497	19	Gravel (Water)
497	500	3	Clay

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 478 to 497 ft.

Other aquifers: 420-435
290-305
250-265

First water at 110 feet.

Casing perforated
from 230 to 500 ft.

Size of perforations
1/8" X 20"

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
10" ID	0	230	230	Cemented from 0 to 80 feet Graveled packed from 80 to 230 feet 5 yards of cement

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailed tested, draw down to 235 feet at 20 GPM

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Drill & Pump Serv.
Well Driller

By A. F. Effinger

License No. 212

Dated July 2, 19 59

(Not to be filled in by Driller)

1959 SEP 15 PM 12 58

1959 AUG 14 PM 1 25

OFFICE ENGINEER

OFFICE ENGINEER