WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 4808
Rec. 19
Well No. .....
Permit No. 18004
Do not fill in

Owner: Permit No. Hoyds Motel
Driller: S.R. Mc Kinney & Son
Address: L.A. Highway South
Address: 1042 So. Main
Lic. No. 45
Location of well: SW ¼NW¼ Sec 28, T24 N/S, R61 E, in Clark County

or .....

Water will be used for: Quasi Municipal
Total depth of well: 250 ft.

Size of drilled hole: 12" to 50 ft., 10" to 250ft.
Weight of casing per linear foot: 10 Gauge

Thickness of casing: 10 Gauge
Temp. of water .....

Diameter and length of casing: 8 5/8 in diameter from 0 ft. to 254 ft.
(Casing 12" in diameter give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure .....

If nonflowing well give depth of standing water from surface: 14 ft.

If flowing well describe control works .....
(Type and size of valve, etc.)

Date of commencement of well: 6/11/59
Date of completion of well: 6/19/59

Type of well rig: Bucyrus Erie 24 L.

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	2	2	Gravel & Sand
2	11	9	Caliche
11	35	24	Caliche with clay streaks
35	45	10	Brown sandy clay
45	51	6	Gravel (Water)
51	75	24	Gravel & Caliche
75	96	21	Brown sandy clay
96	100	4	Caliche
100	126	26	Red clay & gravel
126	130	4	Brown sandy clay
130	135	5	Gravel (Water)
135	190	55	Red sandy clay
190	201	11	Gravel & clay (Water)
201	215	14	Sandy clay
215	221	6	Gravel (Water)
221	225	4	Sandy clay
225	227	2	Gravel
227	235	7	Sandy clay
235	237	2	Gravley clay
237	242	5	Sandy clay
242	250	8	Gravely clay (Water)

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 242 to 250 ft.

Other aquifers
215 to 221 ft.
190 to 201
130 to 135
45 to 51 ft.

First water at 45 feet.

Casing perforated
from Casing Staggered to ..... ft.
every 20 ft.

Size of perforations
3/16 x 10"

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8 5/8"OD	)	254	254	Cemented well with 3½ yds of cement.down to 50ft.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailed 40 GPM at 60 ft., water level 14 ft.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed S.R. Mc Kinney & Son

By M. E. Mc Kinney

License No. 45

Dated 8/8, 19 59

(Not to be filled in by Driller)