

Need Copy

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Log No. 5334
Rec. July 29 1960
Well No.
Permit No. 19020
Do not fill in



Owner Ace Trailer Court (Clyde Ashby) Driller McIntyre Drilling & Pump Serv

Address 3465 Nellie Blvd. Address 3465 West Duncan Drive Lic. No. 2

Location of well: NE 1/4, SE 1/4, Sec. 8, T. 20 N/S, R. 62 E, in Clark

or 3465 Nellie Blvd

Water will be used for Quasi-Municipal Total depth of well 300 feet

Size of drilled hole 12 inch Weight of casing per linear foot

Thickness of casing 6 Gauge Temp. of water

Diameter and length of casing 8" ID 300 feet
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface 76' from top of casing

If flowing well describe control works

Date of commencement of well July 11, 1960 Date of completion of well July 15, 1960

Type of well rig "72 Speed Star"

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material	Water-bearing Formation, Casing Perforations, Etc.
0	76	76	Yellow Clay	
76	84	8	Limestone (Water)	
84	98	14	Yellow Clay	
98	105	7	Limestone (Water)	
105	123	18	Yellow Clay	
123	137	14	White Clay & Lino (Water)	
137	148	11	Red Clay	
148	163	15	Red Sticky Clay	
163	169	6	Limestone (Water)	
169	173	4	Yellow Sticky Clay	
173	183	10	Sand & Gravel (Water)	
183	197	14	Yellow Clay	
197	201	4	Limestone (Water)	
201	221	20	Yellow Sticky Clay	
221	235	14	Limestone (Water)	
235	252	17	Yellow Clay	
252	264	12	Limestone (Water)	
264	274	10	Clay	
274	280	6	Limestone (Water)	
280	300	20	Brown Clay	

Chief aquifer (water-bearing formation)
from 221 to 235 ft.

Other aquifers: 262-264
197-201
173-183
163-169
123-137
98-105

First water at 76 feet.

Casing perforated
from to ft.

Side of perforations

LOG OF FORMATIONS—Continued

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	Remarks—Seals, Grouting, Etc.
8" ID	0	300	300	Cemented from 0 to 50 feet 3 yards of cement 7 yards of pea gravel

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Effinger Drilling Co Pump Service
Well Driller

By [Signature]
License No. 214

Dated July 15, 19 60

(Not to be filled in by Driller)

15 6 19 60

STATE ENGINEER
OFFICE