Log No. 5629
Rec. Jan 3 19 61
Well No.
Permit No. 19131
Do not fill in

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Owner: W. J. Thompson Company Driller: Patrick H. Thompson

Address: 233 View Dr. Las Vegas, Nev. Address: 217 S. 26th St. L.V.N. Lic. No. 192

Location of well: SW 1/4 NW 1/4 Sec. 17, T 21 N/S, R 61 E, in Clark County

or S 1/2 SE 1/4 SW 1/4 SW 1/4 NW 1/4

Water will be used for: Commercial Total depth of well: 150'

Size of drilled hol: 12" to 50' - 10" from 50 to 150 Weight of casing per linear foot: 12#

Thickness of casing: 10 gauge Temp. of water: cold

Diameter and length of casing: 8-5/8" dia. - 151' length
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface: 40'

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well: Aug. 25, 1960 Date of completion of well: Aug. 30, 1960

Type of well rig: Cable tools

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	3	3	brown clay
3	20	17	caliche
20	22	2	brown clay
22	25	3	caliche
25	40	15	brown clay
40	50	10	caliche
50	53	3	br wn clay
53	55	2	caliche - water
55	85	30	brown clay
85	95	10	brown sandy clay
95	100	5	gravel - water
100	110	10	brown sandy clay
110	112	2	gravel - water
112	120	8	brown sandy clay
120	125	5	gravel - water
125	140	15	brown sandy clay
140	145	5	gravel - water
145	150	5	brown clay

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 95 to 100 ft.

Other aquifers: 110 - 112
120-125
140 - 145

First water at 53 feet.

Casing perforated
from 90 to 150 ft.

Size of perforations
3/16 x 12 - 4 rows

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
8-5/8	+1	150	151	Cemented to 50' Graveled from 50' to 150'

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bailed 40 G. P. M. from 75'

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Patrick H. Thompson
Well Driller

By.....

License No. 192

Dated Nov. 15, 19 60

(Not to be filled in by Driller)