WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

Log No. 5697
Rec. 2-14 1961
Well No.
Permit No.
Do not fill in

Owner: Quiriconi Armida — Driller: Meyer Drilling Co.

Address: Dayton, Nev. — Address: Carson City, Nev. — Lic. No. 209

Location of well: ¼ ¼ Sec. 23, T. 16 N/~~S~~ R. 21 E, in Lyon County

or West part of Dayton

Water will be used for: domestic — Total depth of well: 96 Feet

Size of drilled hole: 6 inch — Weight of casing per linear foot: 10 #

Thickness of casing: .219 wall — Temp. of water: cool

Diameter and length of casing: 6 inch x 96 Feet
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure: none

If nonflowing well give depth of standing water from surface: 25 feet

If flowing well describe control works: none
(Type and size of valve, etc.)

Date of commencement of well: Feb. 6, 1961 — Date of completion of well: Feb. 9, 1961

Type of well rig: Cable Tool 71 Star

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	5	5	Top soil & Rock
5	45	40	Sand & Loose Rock
45	55	10	Sand
55	80	25	Rock & Clay
80	96	16	Rock

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 80 to 96 ft.

Other aquifers

First water at 50 feet.

Casing perforated

from 76' to 96' ft.

Size of perforations

1/8 X 6"
torch

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
6"	0	96	96	Star Drive Shoe

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Bail test 12 GPM @ 80 feet

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed MEYER DRILLING CO., INC. CARSON CITY, NEVADA
Well Driller

By Bob Meyer

License No. 209

Dated Feb. 11, 19 61

(Not to be filled in by Driller)

1961 FEB 14 AM 8 42

STATE ENGINEER OFFICE