Log No. 5974
Rec. June 27 1961
Well No.
Permit No. 17973
Do not fill in

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

To Replace Lost Log

Owner: Teresa Mahoney Driller: Les Harvey
Address: Beowawe Address: Winnemucca Lic. No. 170

Location of well: SW ¼ SE ¼ Sec. 31, T. 32 N/S, R. 49 E, in Eureka County
or

Water will be used for: Irrigation Total depth of well: 450 feet.
Size of drilled hole: 14" Weight of casing per linear foot:
Thickness of casing: 1/4" Temp. of water: Cold.
Diameter and length of casing: 14" to 204 ft. – 10" to 380 ft. 8" to 450 ft.
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure:
If nonflowing well give depth of standing water from surface: 16 ft.
If flowing well describe control works:
(Type and size of valve, etc.)
Date of commencement of well: Date of completion of well:
Type of well rig: 71 Star Spudder.

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	3	3	Topsoil.
3	114	101	loose gravel
114	204	110	cement & gravel
204	219	15	gravely Clay.
219	381	162	clay w/ thin sand streaks
381	420	39	Volcanic Rock
420	450	30	Water sand & gravel

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 420 to 450 ft.

Other aquifers: some – 16 – 114
some – 219 – 381

First water at 16 feet.

Casing perforated
from ..... to ..... ft.

Size of perforations
1/4 x 2

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Pump test showed well should pump 2000 g.p.m. from 140 ft.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed Les Harvey
Well Driller

By.....

License No. 170

Dated 5/29, 1961

(Not to be filled in by Driller)

1961 JUN 27 AM 9 22

OFFICE
STATE ENGINEER

Jacuzzi Bros. Inc.

SALES NO. № 6908

Ship From
- ☐ RICHMOND, CALIFORNIA
- ☐ ST. LOUIS, MISSOURI
- ☐ PORTLAND, OREGON
- ☐ BINGHAMTON, NEW YORK
- ☐ KANSAS CITY, MISSOURI
- ☐ NEEDHAM HEIGHTS, MASS.
- ☐ LOUISVILLE, KENTUCKY
- ☐ MONTERREY, MEXICO
- ☐ DALLAS, TEXAS
- ☐ ORLANDO, FLORIDA
- ☐ DENVER, COLORADO
- ☐ HOUSTON, TEXAS
- ☐ ATLANTA, GEORGIA
- ☐ TORONTO, CANADA
- ☐ MINNEAPOLIS, MINNESOTA
- ☐ LOS ANGELES, CALIFORNIA
- ☐ RICHMOND, VIRGINIA
- ☐ MILWAUKEE, WISCONSIN

Subject to Our Published Conditions of Sale

Date _____ Requested Shipping Date _____

SOLD TO: Well Test for-
Mrs. Mahoney

SHIPPED TO:

CUSTOMER'S ORDER DATE	NO.	SLSM NO.	CLASS	SHIP VIA	TERMS OF PAYMENT	CREDIT DEPT.

ITEM	QUAN.	CATALOG NUMBER	DESCRIPTION	LIST	TOTAL	DISC.	NET
			Discharge of Pipe 8 1/8"				
			G.P.M Per ft of V = 165 G.P.M				
	Vol	G.P.M	P.R.				
	9.0	1500	71' - 17 - 725 - 42.5				
	8.2	1350	69 - 16 - 585 - 39				
	7.4	1220	67 - 13 - 445 - 33				
	6.5	1070	64 - 10 - 295 - 29 1/2				
	6.0	990	61 - 7 - 215 - 30				
	4.7	775	54 - 0 -				
			QR Point 38				
		1500	71 - 38 = 33' = 725 = 45				
		1350	69 - 38 = 31' = 5 = 44				
		1220	67 - 38 = 29' = 42				
		1070	64 - 38 = 26' = 41				
		990	61 - 38 = 23' = 43				
		775	54 - 38 = 16' = 47				
			G.P.M Per ft Abot 40 G.P.M-				

SPECIAL INSTRUCTIONS:

1500 - 71
2020 13 x 42 = 520
84 Shorty about 2000 at 700"

Firm Name _____

Signature _____

Salesman's Signature

(Original Order)