WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 6016
Rec. July 19 1961
Well No.
Permit No.
Do not fill in

PLEASE COMPLETE THIS FORM IN ITS ENTIRETY

8-211-07

Owner Gordon H Millard Driller W E Blair

Address 326 E John St Carson City Address Box 255 Carson City Lic. No. 311

Location of well: NW ¼ NW ¼ Sec. 10, T 15 N/S, R 20 E, in Ormsby County

BBCB

[illegible]

Water will be used for Domestic Total depth of well 59 ft

Size of drilled hole 10" to 16 ft Weight of casing per linear foot 5.81 lbs

Thickness of casing 10 gage Temp. of water Cold

Diameter and length of casing 6" x 60 ft
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter.)

If flowing well give flow in c.f.s. or g.p.m. and pressure

If nonflowing well give depth of standing water from surface 21 ft

If flowing well describe control works
(Type and size of valve, etc.)

Date of commencement of well 6-23-61 Date of completion of well 6-24-61

Type of well rig Cable Tool

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	3½	3½	soil
3½	8	4½	hard pan
8	16	8	Sandy Clay
16	22	6	Green Clay
22	50	8	Brn Sandy Clay
50	58	8	Sand
58	59	1	Clay

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)

from 50 to 58 ft.

Other aquifers 45-50

First water at 45 feet.

Casing perforated

from 52 to 60 ft.

Size of perforations

5" x ⅛"

(OVER)

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks"—Seals, Grouting, Etc.
6"	0	59	60	1 ft above ground
				Cemented to depth of 16 ft

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

Test by bailing - apt 24 [illegible]

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed [illegible]
Well Driller

By [illegible]

License No. 301

Dated July 17, 1961

(Not to be filled in by Driller)

1961 JUL 19 AM 9 14

STATE ENGINEER
OFFICE