Need 1 copy

WELL LOG AND REPORT TO THE STATE ENGINEER OF NEVADA

Log No. 6417
Rec. Mar. 12 1962
Well No.
Permit No. 19219
Do not fill in

Owner: Stocks Mill and Supply Co.
Driller: ALLEN WATER WELL SERVICE CO.
Address: 750 Fremont St.
Address: 911 So. Main St. Lic. No. 40
Location of well: NW ¼ SW ¼ Sec. 17, T 21 N/S, R 61 E, in Clark County
or: Stocks gravel plant cinderlite road.

Water will be used for: commerical
Total depth of well: 588'
Size of drilled hole: 12"
Weight of casing per linear foot: 13 lbs.
Thickness of casing: 10 gauge
Temp. of water:
Diameter and length of casing: 8-5/8" O.D 0 to 588'
(Casing 12" in diameter and under give inside diameter; casing 12" in diameter give outside diameter)

If flowing well give flow in c.f.s. or g.p.m. and pressure:
If nonflowing well give depth of standing water from surface: 20'
If flowing well describe control works:
(Type and size of valve, etc.)

Date of commencement of well: Oct. 1960
Date of completion of well: Oct. 17, 1960
Type of well rig: Motors rig.

LOG OF FORMATIONS

From feet	To feet	Thickness feet	Type of material
0	10	10	sand and gravel
10	15	5	caliche
15	18	3	sand
18	22	4	caliche
22	26	4	sand
26	36	10	sand and gravel
36	48	12	caliche
48	90	42	sand and gravel
90	95	5	red clay
95	133	38	coarse sand
133	146	13	clay
146	154	8	clay and gravel
154	259	105	sandy clay
259	282	23	coarse sand
282	305	23	clay and gravel
305	338	33	clay
338	351	13	clay sand and gravel
351	373	22	coarse gravel
373	383	10	sand and gravel
383	395	12	coarse sand with gravel
395	418	23	cemented gravel
418	440	22	clay
440	463	23	clay
463	483	20	yellow clay
483	528	45	clay and gravel
528	588	50	coarse sand and gravel

(OVER)

Water-bearing Formation, Casing Perforations, Etc.

Chief aquifer (water-bearing formation)
from 351 to 395 ft.

Other aquifers 95-113 259-282 528-588

First water at 48 feet.

Casing perforated
from 350 to 588 ft.

Size of perforations
5 around on 14" centers.

919

LOG OF FORMATIONS—*Continued*

From feet	To feet	Thickness	Type of material

CASING RECORD

Diam. casing	From feet	To feet	Length	"Remarks" Seals Grouting Etc
8-5/8 O.D.	0	588	588	Gravel packed with 3/8" pea gravel 50' to 588. Top 50 feet cemented in place.

GENERAL INFORMATION—Pumping Test, Quality of Water, Etc.

WELL DRILLER'S STATEMENT

This well was drilled under my jurisdiction and the above information is true to my best information and belief.

Signed ALLEN WATER WELL SERVICE CO.
Well Driller

By [signature]

License No. 40

Dated Feb. 9, 1961

(Not to be filled in by Driller)

1962 MAR 12 AM 10 53

STATE ENGINEER
OFFICE